Faculty Work Comprehensive List

1991

Methods of Measuring the Solubility and Viscosity of Lubricating Oil/Refrigerant Mixtures at High Discharge Pressures and Temperatures

Nolan Van Gaalen

Dordt College, nolan.vangaalen@dordt.edu

Follow this and additional works at: https://digitalcollections.dordt.edu/faculty_work

Part of the [Chemical Engineering Commons](#), and the [Mechanical Engineering Commons](#)

Recommended Citation

Van Gaalen, N. (1991). Methods of Measuring the Solubility and Viscosity of Lubricating Oil/Refrigerant Mixtures at High Discharge Pressures and Temperatures. Retrieved from https://digitalcollections.dordt.edu/faculty_work/132

This Dissertation is brought to you for free and open access by Dordt Digital Collections. It has been accepted for inclusion in Faculty Work Comprehensive List by an authorized administrator of Dordt Digital Collections. For more information, please contact ingrid.mulder@dordt.edu.

Methods of Measuring the Solubility and Viscosity of Lubricating Oil/Refrigerant Mixtures at High Discharge Pressures and Temperatures

Abstract

The design and construction of a test facility and methodology for measuring the solubility and viscosity of lubricating oil/refrigerant mixtures at high pressures and temperatures are described. An auxiliary charging system, developed to provide precisely measured quantities of oil and refrigerant to the test facility, is also presented. The test facility was developed under the sponsorship and supervision of ASHRAE which funded this research project (RP-580);The solubility, viscosity and density of mixtures of R-22 and of R-502 with commonly used 150 SUS lubricants have been measured by using this facility. Specifically, results for liquid mixtures of 10% to 40% refrigerant (by mass) in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene are reported over the temperature range of 100 degrees F (38 degrees C) to 300 degrees F (149 degrees C). The oil/refrigerant mixtures for R-22 were miscible over the complete range tested, while for the R-502/naphthenic oil mixtures, two coexistent liquid phases were encountered in tests at the higher refrigerant concentrations;The property test results are presented in graphical form as well as in the form of empirical correlations based on a nonlinear regression analysis of the experimental data. Comparisons with the limited data previously published in the open literature show reasonable agreement.

Keywords

ASHRAE, compressor design, lubricating oil, refrigerant mixtures, viscosity

Disciplines

Chemical Engineering | Mechanical Engineering

Comments

- A dissertation submitted to the graduate faculty of Iowa State University in partial fulfillment for the degree of DOCTOR OF PHILOSOPHY
- Dr. Michael B. Pate, Committee Chairperson
- © 1991 Nolan A. Van Gaalen

**Methods of Measuring the Solubility and Viscosity
of Lubricating Oil/Refrigerant Mixtures
at High Discharge Pressures and Temperatures**

by

Nolan A. Van Gaalen

A Dissertation Submitted to the
Graduate Faculty in Partial Fulfillment of the
Requirements for the Degree of
DOCTOR OF PHILOSOPHY

Major: Mechanical Engineering

Approved:

Signature was redacted for privacy.

In Charge of Major Work

Signature was redacted for privacy.

For the Major Department

Signature was redacted for privacy.

For the Graduate College

Iowa State University
Ames, Iowa
1991

TABLE OF CONTENTS

ACKNOWLEDGEMENTS	x
CHAPTER 1. INTRODUCTION	1
CHAPTER 2. OIL/REFRIGERANT TEST FACILITY	4
Design of Experimental Apparatus	4
Description of the Oil/Refrigerant Test Facility	6
Description of the Oil/Refrigerant Charging Station	19
Summary	23
CHAPTER 3. EXPERIMENTAL PROCEDURES AND DATA	
REDUCTION	25
General Experimental Procedures	25
System Calibration Check	30
Data Reduction	39
Summary	42
CHAPTER 4. R-22 AND OIL SOLUTION PROPERTY RESULTS	43
Results and Discussion	43
Summary	62
CHAPTER 5. R-502 AND OIL SOLUTION PROPERTY RESULTS	66

Results and Discussion	67
Summary	85
CHAPTER 6. CONCLUSIONS AND RECOMMENDATIONS . .	88
Recommendations for Future Work	89
BIBLIOGRAPHY	91
APPENDIX A. TEST FACILITY CONSTRUCTION DETAILS . .	93
APPENDIX B. UNCERTAINTY ANALYSIS	103
Uncertainties of the Pressure, Temperature, and Viscosity Data	103
Uncertainty of the Liquid Density	105
Uncertainty of the Liquid Composition	114
APPENDIX C. LISTING OF EXPERIMENTAL DATA	118

LIST OF TABLES

Table 2.1:	Summary of instrumentation ranges and precision	18
Table 3.1:	Calibration of viscosity sensor	30
Table 4.1:	Coefficients for Empirical Correlations of Viscosity, Pressure, and Density Data for R-22/oil Solutions	45
Table 5.1:	Coefficients for empirical correlations of viscosity, pressure, and density data for R-502/oil solutions	68
Table A.1:	List of test facility components	98
Table A.2:	List of charging station components	101
Table C.1:	Experimental solubility (vapor pressure) data for R-22/150 SUS naphthenic oil solutions	120
Table C.2:	Experimental viscosity data for R-22/150 SUS naphthenic oil solutions	123
Table C.3:	Experimental density data for R-22/150 SUS naphthenic oil solutions	125
Table C.4:	Experimental solubility (vapor pressure) data for R-22/150 SUS alkylbenzene solutions	127

Table C.5:	Experimental viscosity data for R-22/150 SUS alkylbenzene solutions	130
Table C.6:	Experimental density data for R-22/150 SUS alkylbenzene solutions	133
Table C.7:	Experimental solubility (vapor pressure) data for R-502/150 SUS naphthenic oil solutions	136
Table C.8:	Experimental viscosity data for R-502/150 SUS naphthenic oil solutions	138
Table C.9:	Experimental density data for R-502/150 SUS naphthenic oil solutions	140
Table C.10:	Experimental solubility (vapor pressure) data for R-502/150 SUS alkylbenzene solutions	142
Table C.11:	Experimental viscosity data for R-502/150 SUS alkylbenzene solutions	144
Table C.12:	Experimental density data for R-502/150 SUS alkylbenzene solutions	146

LIST OF FIGURES

Figure 2.1:	Oil/refrigerant test facility	7
Figure 2.2:	Test cell assembly schematic	9
Figure 2.3:	Oil/refrigerant test facility schematic	10
Figure 2.4:	Viscosity-temperature sensor body	14
Figure 2.5:	Oil/refrigerant charging facility	20
Figure 2.6:	Oil/refrigerant charging facility schematic	21
Figure 3.1:	R-22 vapor pressure data	31
Figure 3.2:	Solubility data for mixtures of R-22 and a 150 SUS naphthenic oil	33
Figure 3.3:	Viscosity data for mixtures of R-22 and a 150 SUS naphthenic oil	34
Figure 3.4:	Test of repeatability of solubility measurements for 30% R-22 in a 150 SUS naphthenic oil	35
Figure 3.5:	Test of repeatability of viscosity measurements for 30% R-22 in a 150 SUS naphthenic oil	36
Figure 3.6:	Solubility data for mixtures of R-22 and a 150 SUS naphthenic oil - comparison with literature	37

Figure 3.7:	Viscosity data for mixtures of R-22 and a 150 SUS naphthenic oil - comparison with literature	38
Figure 4.1:	Goodness-of-fit of pressure correlation with experimental data for solutions of R-22 in a 150 SUS naphthenic oil	46
Figure 4.2:	Goodness-of-fit of viscosity correlation with experimental data for solutions of R-22 in a 150 SUS naphthenic oil	47
Figure 4.3:	Goodness-of-fit of pressure correlation with experimental data for solutions of R-22 in a 150 SUS alkylbenzene	48
Figure 4.4:	Goodness-of-fit of viscosity correlation with experimental data for solutions of R-22 in a 150 SUS alkylbenzene	49
Figure 4.5:	Solubility of R-22 in a 150 SUS naphthenic oil	50
Figure 4.6:	Absolute viscosity of R-22 in a 150 SUS naphthenic oil	51
Figure 4.7:	Density of R-22 in a 150 SUS naphthenic oil	52
Figure 4.8:	Viscosity-temperature-pressure chart for solutions of R-22 in a 150 SUS naphthenic oil	54
Figure 4.9:	Correlation of test results compared with manufacturer's solubility data for solutions of R-22 in a 150 SUS naphthenic oil	56
Figure 4.10:	Solubility of R-22 in a 150 SUS alkylbenzene	57
Figure 4.11:	Absolute viscosity of R-22 in a 150 SUS alkylbenzene	58
Figure 4.12:	Density of R-22 in a 150 SUS alkylbenzene	59
Figure 4.13:	Viscosity-temperature-pressure chart for solutions of R-22 in a 150 SUS alkylbenzene	60

Figure 4.14: Correlation of test results compared with previously reported solubility data for solutions of R-22 in a 150 SUS alkylbenzene	61
Figure 4.15: Correlation of test results compared with estimates of viscosity data for solutions of R-22 in a 150 SUS alkylbenzene . . .	63
Figure 4.16: Comparison of the solubility of R-22 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene	64
Figure 4.17: Comparison of the viscosity of R-22 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene	65
Figure 5.1: Goodness-of-fit of pressure correlation with experimental data for solutions of R-502 in a 150 SUS naphthenic oil	69
Figure 5.2: Goodness-of-fit of viscosity correlation with experimental data for solutions of R-502 in a 150 SUS naphthenic oil	70
Figure 5.3: Goodness-of-fit of pressure correlation with experimental data for solutions of R-502 in a 150 SUS alkylbenzene	71
Figure 5.4: Goodness-of-fit of viscosity correlation with experimental data for solutions of R-502 in a 150 SUS alkylbenzene	72
Figure 5.5: Solubility of R-502 in a 150 SUS naphthenic oil	74
Figure 5.6: Absolute viscosity of R-502 in a 150 SUS naphthenic oil . . .	75
Figure 5.7: Density of R-502 in a 150 SUS naphthenic oil	76
Figure 5.8: Viscosity-temperature-pressure chart for solutions of R-502 in a 150 SUS naphthenic oil	78
Figure 5.9: Correlation of test results compared with manufacturer's solubility data for solutions of R-502 in a 150 SUS naphthenic oil	79

Figure 5.10: Solubility of R-502 in a 150 SUS alkylbenzene	80
Figure 5.11: Absolute viscosity of R-502 in a 150 SUS alkylbenzene	81
Figure 5.12: Density of R-502 in a 150 SUS alkylbenzene	82
Figure 5.13: Viscosity-temperature-pressure chart for solutions of R-502 in a 150 SUS alkylbenzene	83
Figure 5.14: Correlation of test results compared with previously reported solubility data for solutions of R-502 in a 150 SUS alkylbenzene	84
Figure 5.15: Comparison of the solubility of R-502 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene	86
Figure 5.16: Comparison of the viscosity of R-502 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene	87
Figure A.1: Working drawing of pressure vessel	95
Figure A.2: Window frame details	96
Figure A.3: Window assembly details	97

ACKNOWLEDGEMENTS

This study was sponsored by ASHRAE as Research Project RP-580. The support of ASHRAE and the advice of the RP-580 Monitoring Committee are gratefully acknowledged. In particular, I wish to thank Jack O'Brien, Kanaya Sanvordenker, Glenn Short, and Carl Speich, for their interest, encouragement, and helpful advice. In the early stages of the project, Ken Puetzer and Paul Tietze also served on this committee. Thanks are also extended to Witco Corp. (Sonneborn Division) and to Shrieve Chemical Co. for the donation of lubricating fluids for testing.

Beyond this, I am grateful to Dr. Michael Pate, without whose insight, generosity, and moral support, this project would not have been completed. Throughout this research project, he has been an effective teacher, technical advisor, and counsellor for me, especially during the more difficult challenges encountered during this work. I also wish to thank Dr. John Eggebrecht, Dr. Jerry Hall, Dr. Ron Nelson, and Dr. Howard Shapiro, who served on my doctoral committee and reviewed the dissertation.

A special acknowledgement is due to Steve Zoz, who helped to design and build the oil/refrigerant charging station and provided much technical assistance in both the construction and operation of the test facility. I have also benefitted from interactions with other graduate student colleagues, especially Joe Huber and Steve Eckels,

who readily shared their computer systems expertise and practical laboratory experience with me. I will remember with appreciation the philosophical, as well as technical, discussions with them and with "Rajan" Natarajan, Halim Wijaya. Dick Rusk, Bob Bittle, Don Gauger, and Steve Crown. For enthusiastically and frequently sharing the tastes of China, my family and I heartily thank Liang Yong and Ping Liu and their families.

I owe more than I can say to my wife Dorenda, who has lovingly supported and encouraged me in many ways through both the joys and frustrations of our time at Iowa State University, and has provided more than her share of the care and nurture of our daughter Joelle, while also pursuing her studies.

Finally, those who know me well will understand my ready acknowledgement of the blessings of the Lord. Believing that all of reality has an ultimate meaning when seen in reference to a Creator God who also sustains and redeems it, I have tried to view and do my work also within that context. Accordingly, one aspect of the relevance of this work, as I see it, is the extent to which it somehow contributes to better stewardship of energy resources and the environment within the refrigeration industry in its transition to alternative working fluids.

CHAPTER 1. INTRODUCTION

Recent advances in screw and rolling piston compressor design have resulted in a need for data on the viscosity and solubility of oil/refrigerant mixtures at high pressures and temperatures. Data on the viscosity and solubility of oil/refrigerant pairs exist in the literature for a limited pressure and temperature range. For example, ASHRAE (1990) has published data from various sources that provide viscosities of these mixtures up to a maximum temperature of 140°F (60°C). Further, for some important combinations of oil and refrigerants, data at any conditions are hard to find or unavailable in the open literature. This is increasingly important as the industry searches for alternative refrigerants and appropriate lubricants. An ASHRAE-sponsored research project, RP-444 (Spauchus 1987), documented the published works in this area, concluding that fewer than 20 references exist on the viscosities of oil/refrigerant mixtures.

Responding to this need for data, ASHRAE sponsored a research project, RP-580, to develop a method for measuring the solubility and the viscosity of oil/refrigerant mixtures at high pressures and temperatures. This need was recognized by ASHRAE as early as 1977 when TC 3.4 (Lubrication) sponsored a Forum at the ASHRAE Winter Meeting to discuss industrial needs for expanded data on oil/refrigerant mixtures. The early 1980's saw the formation of a consensus between

TC' 3.4 and TC' 8.1 (Positive Displacement Compressors), culminating in a joint work statement recommending "a study to increase the state of the art of solubility and viscosity relationships for lubricating oil/refrigerant mixtures."

The ensuing research project, RP-444, was completed in 1986 and a paper summarizing its findings was presented in 1987 (Spauchus and Speaker 1987). This research included a survey of the existing solubility and viscosity data, finding that a "lack of uniformity in experimental data and data reporting," especially with regard to systems of units and manner of presentation, made comparison of the results difficult. The researchers also reviewed the available experimental methods of determining this data and studied algorithms that could be used to correlate viscosity data, discovering that "reliable results can be obtained by various methods and equipment. No single method or apparatus has been identified that simplifies the measurements and readily extends the range of the viscosity data that can be acquired." They therefore concluded that there existed a "need for experimental studies by validated means on selected [oil/refrigerant] solutions to serve as models for the generation of a complete data base."

Following the conclusion of RP-444, ASHRAE TC's 3.4 and 8.1 jointly issued a work statement titled "Methods of Measuring the Solubility and Viscosity of Lubricating Oil/Refrigerant Mixtures at High Discharge Pressures and Temperatures." This document outlined the scope of the present research project, RP-580. The objectives of this research project included the development of a methodology for "measurement of solubility and viscosity data for common oil/refrigerant mixtures to static pressures of [at least] 450 psia and temperatures of 150 degrees Celsius." The apparatus was to meet the criteria of high reproducibility, engineering accuracy,

ease of construction, reasonable cost, and, if feasible, commercial availability. The correctness of the results was to be proven by tests using several refrigerants and commonly used lubricants. The data sets for the chosen oil/refrigerant pairs were to be extended to the maximum pressure and temperature limits of 450 psia (3.1 MPa) and 300 °F (150 °C).

Consultations with the monitoring committee established that four oil/refrigerant pairs were to be studied so that the results could be compared with existing data in order to prove the methodology. These pairs were:

1. R-22 and a 150 SUS naphthenic mineral oil
2. R-22 and a 150 SUS alkylbenzene lubricant
3. R-502 and a 150 SUS naphthenic mineral oil
4. R-502 and a 150 SUS alkylbenzene lubricant

The following chapters discuss the test facility and the methodology which has been developed to meet the above research objectives. Results for the oil/refrigerant pairs studied are presented in the form of graphs and empirical correlations and compared with the limited existing data. Additionally, appendices contain detailed construction information and drawings, an uncertainty analysis, and a tabulation of the actual data points.

CHAPTER 2. OIL/REFRIGERANT TEST FACILITY

The experimental apparatus described in this chapter includes a multipurpose test cell capable of withstanding and controlling the high temperatures and pressures present in the oil/refrigerant mixtures undergoing experimental tests. Additional equipment is an auxiliary flow loop for measuring liquid viscosity and for sampling. Transducers for measuring viscosity, temperature, and pressure are installed in the flow loop and the test cell. The facility was designed to measure solubility, viscosity, and density for any oil/refrigerant mixture over a normal operating temperature range of 70°F (20°C) to 300°F (150°C), and at pressures up to 500 psia (3.5 MPa). By interfacing an appropriate cooling unit, the test facility can also be used to evaluate oil/refrigerant mixtures at low temperatures, e.g., -40°F (-40°C).

Design of Experimental Apparatus

The design of the test facility began with general requirements that were then used to develop detailed specifications to guide the actual construction of the test facility. These design criteria, equipment and instrumentation descriptions, and operating procedures are given in the following sections.

General requirements

The general requirements used to guide the design of the test facility were:

1. Construction with commercially available components and/or readily manufacturable parts.
2. Wide mixture concentration range (0 to 100% refrigerant).
3. Temperatures from 140°F (60°C) to approximately 300°F (150°C).
4. Pressures up to 500 psia (3.5 MPa).

Detailed specifications

The detailed specifications developed to meet the general requirements were:

1. Batch-type operation, with sufficient liquid to supply viscometer and adequately submerge temperature probes.
2. Overall volume sufficient to (a) contain the addition of refrigerant up to liquid concentrations of 40% refrigerant/ 60% oil at all expected densities, (b) provide for thermal expansion of the liquid due to heating, and (c) mount a temperature probe in a vapor space.
3. Cylindrical test cell to allow for ease of manufacture from pipe stock. Minimum diameter to contain internal probes and sufficient liquid, ensuring most rapid attainment of equilibrium and uniform temperature profile upon heating.
4. Wall thickness sufficient to safely withstand internal pressure and to permit the machining of appropriately sized O-ring grooves used to seal the ends.

5. Test cell material to be stainless steel, type 304, for toughness and chemical stability in normal operation.
6. Two independent measurements of liquid temperature, one measurement of vapor temperature and several measurements of test cell wall temperature to check thermal gradients.
7. Pressure, viscosity, and mixture composition determination of highest practical accuracy.
8. Uniform mixing ensured by pumping action.

Description of the Oil/Refrigerant Test Facility

On the basis of these general and specific considerations, the necessary equipment was designed and built. The major components, including the test cell, the viscometer and sampling loops, and a temperature control flow loop, are housed in an enclosure as shown in Figure 2.1. These system components, as well as the instrumentation for data acquisition and an auxiliary charging system to inject fluids into the test cell, are described in the following sections.

Test cell

The test cell is a cylinder constructed of Schedule 120 Type 304 stainless steel pipe, with an outside diameter of 5.563 in. (141.3 mm), a wall thickness of 0.500 in. (12.7 mm), and a corresponding inside diameter of 4.563 in. (115.9 mm). The height of the internal volume is 18 in. (457.2 mm). The test cell stands upright on one end. Two diametrically opposite slots 12.5 in. (317.5 mm) in length were

Figure 2.1: Oil/refrigerant test facility

machined through the cylinder wall. Windows bolted into position over these slots allow for visual inspection of the contents at all times and under all test conditions. A schematic drawing of the test cell is provided in Figure 2.2 while detailed line drawings are provided in Appendix A.

Machined end plates 1 in. (25.4 mm) thick are bolted onto flanges welded to the pipe section at each end. O-rings at each end, seated in machined grooves in the wall of the pipe section, provide the pressure (and vacuum) seals. Because none of the weld joints are exposed to the contents of the test cell, this method of construction obviates the need for inspection of welds for leakage that would be required by other designs. The height of the test cell is sufficient to accommodate the addition of 40% (by mass) refrigerant to the initial oil charge, while still reserving a minimum vapor space at all expected densities and at maximum charge conditions.

Entering the test cell through the top end plate are three temperature probes and a heating/cooling coil, as depicted in Figure 2.2. Also provided in the top plate are ports for pressure measurement and pressure relief, as well as for filling and evacuation of the test cell. Two ports machined into the bottom plate allow for the exit and return of fluid to/from the external viscometer and sampling loops, as shown in Figure 2.3. Actual volumes of the test cell and associated loops were determined and the scales on the windows calibrated by injecting precise amounts of R-113 from the charging system, which had been previously calibrated. With both windows mounted on the test cell and with the viscometer and sample loops full, the overall volume was measured as $316.5 \text{ in.}^3 \pm 1.2 \text{ in.}^3$ ($5190 \text{ mL} \pm 20 \text{ mL}$). Liquid and vapor volumes were correlated with liquid level height as measured on the scales.

The temperature, and hence pressure, of the solution under test is controlled by

Figure 2.2: Test cell assembly schematic

Figure 2.3: Oil/refrigerant test facility schematic

a temperature control flow loop having coils soldered onto the exterior of the test cell and by a portion of the loop immersed in the test cell. A heating fluid is supplied to this loop by a circulating bath. Uniform heating of a large surface area minimizes the thermal gradients in the oil/refrigerant mixture. Fiberglass insulation, 2 in. (50 mm) thick around the test cell, minimizes heat loss to the environment. A walled enclosure, described elsewhere, also reduces heat losses.

Windows

In order to view the contents of the test cell for the purposes of detecting the presence of more than one liquid phase and for density determinations, as well as aiding the charging of the test cell, two diametrically opposite vertical windows were provided in the test cell wall. The viewing slots are 12 in. (304.8 mm) long and 0.50 in. (12.7 mm) wide (see Figure 2.1). Calibrated scales fastened to the retainer plates adjacent to the viewing slots enable measurement of the height of the liquid-vapor interface to within $\pm 1/32$ inch. This permits determination of the volumes of liquid and vapor present to within ± 9 mL, or less than 0.2% of the total cell volume. Quartz pieces set on O-rings and held in place by retainer plates provide the pressure seal. A stainless steel backing plate holds the quartz against the O-ring in the slot. The whole assembly is then bolted onto the test cell and sealed by another (larger) O-ring compressed between the test cell wall and the window assembly. The O-ring material must be compatible with the oil/refrigerant mixtures to which it will be exposed. Neoprene O-rings were used with the R-22/oil mixtures. Viton O-rings have also proven satisfactory in later work, including the studies of R-502/oil mixtures also reported here. Epichlorhydrin, if available, may also prove to be quite widely

compatible. After installation, a hydrostatic test to 500 psi (3.5 MPa) conducted at ambient temperature proved that the windows were leak-tight. Additional pressure tests with nitrogen gas at 500 psi (3.5 MPa) also showed no leaks.

Temperature control flow loop

A flow loop for controlling the temperature of the test cell is installed. Figure 2.3 shows a schematic diagram of this loop. The loop has two coils of 0.375 in. (9.525 mm) OD Type 304 stainless steel tubing in parallel: one soldered in place around the test cell wall and the other immersed in the test cell through the top plate. The exterior portion of this loop is further divided into two parts, with each part heating one side of the test cell. The interior portion also bifurcates to provide more thermal contact area. The routing of these internal loop portions was arranged so that they did not obstruct the view through the windows.

A circulating bath maintains the desired temperature of the heating fluid by controlling a 3-kW heating element. The heating fluid is a poly-alpha-olefin (PAO), used from 140°F (60°C) to 300°F (150°C). While the viscosity of PAO at the lower end of this temperature range, 140°F (60°C), is high (6-7 cp) for achieving turbulent flow in the loop with the circulating bath pump, it performs well at higher temperatures in an open system because of its decreasing viscosity and extremely low volatility. The steady-state temperature of the contents of the test cell is indirectly controlled by setting the temperature of the heating fluid in the flow loop. Operating experience has shown that adequate heating of the test cell is provided by this arrangement. Steady-state conditions are typically achieved from one to two hours after a 18°F (10°C) change in the circulating bath temperature setpoint. To monitor the magni-

tude of thermal gradients, copper-constantan (Type T) thermocouples were installed in the flow loop as well as on seven different locations on the outer surface of the test cell. At equilibrium, surface temperature differences are on the order of a few degrees. However, since the liquid inside is well stirred, its temperature is more uniform as measured by the internal resistance temperature detectors (RTD). An average of these liquid temperatures is used in the reporting of the liquid density data.

Viscometer

Three commercially available viscosity sensors were procured for installation in the auxiliary viscometer loop (CAS 1989). An early version of this viscosity measuring technology was used as a means of measuring the concentration of oil in the liquid line of a refrigeration system as part of a previous ASHRAE-sponsored research project, RP-356 (Baustian et al. 1988). The viscosity sensor operation is based on a movable piston drawn through the fluid in the internal cavity by an applied electromagnetic field. Figure 2.4 provides a schematic drawing of the internal details (CAS 1989). The time elapsed as the piston travels through a known distance is a measure of the viscosity of the fluid. The associated circuit card provides electronics for control and sensing, giving a 0 to 2 volt d.c. signal correlated to viscosity. The uncertainty of the viscosity data is $\pm 2.0\%$ of the reading. Each sensor also contains an RTD for measurement of the local temperature, which is used in the reporting of the viscosity data. Because of internal self-heating in the viscometer which arises from the dissipation of electrical energy in the drive coils of the sensor, this RTD reading is somewhat higher than the temperatures indicated by the RTDs in the test cell during steady-state operation. This is especially true at the lower end of the

Figure 2.4: Viscosity-temperature sensor body

investigated temperature range. For example, at 40°C the difference is about 3 - 4°C, depending on the particular viscosity sensor. This difference decreases to about zero at temperatures of 90°C and beyond.

The three viscosity sensors that are installed in the viscometer chamber have viscosity ranges of 0.1-2 cp, 1-20 cp, and 10-200 cp, respectively. Because these ranges overlap, some limited redundant measurements of viscosity are possible, thus increasing the confidence in the validity of the calibrations of each sensor. Use of multiple sensors reduces the downtime that would otherwise be required to change the internal piston of a single sensor to the desired measurement range. Pistons are available from the manufacturer for viscosities up to 5000 cp, should they be necessary for measurements at low temperatures where the oil/refrigerant solutions may be very viscous. These solutions are assumed to be "Newtonian" fluids in which the viscosity is independent of shear rate. Discussions with experienced users of these fluids confirmed that this assumption is reasonable.

The viscosity of the liquid is measured outside the test cell in an auxiliary flow loop. Because internal self-heating in the drive coils of the viscometer tends to cause vapor to flash from the equilibrium liquid mixture, it was necessary to construct an external flow loop through which compressed liquid could be pumped to the viscometer for measurement and then returned to the test cell. In this manner, stable and repeatable viscosity readings were achieved. The viscosity test loop complements the test cell, which sets the conditions of concentration, temperature, and pressure at desired values, prior to measuring viscosity. Taking liquid from the test cell, a pump raises the pressure of the liquid without noticeably affecting the temperature. Since a small increase in pressure has a negligible effect on liquid viscosity, this pressurization

provides a means of preventing vapor formation in the viscometer. Early operating experiences with a different viscometer-mounting configuration showed that vapor formation is disruptive to stable and accurate operation of the viscometer.

As shown in Figures 2.1 and 2.3, a magnetically driven positive-displacement gear pump with a variable-speed motor moves the fluid through this loop to the viscometer chamber and back to the test cell. Variable-speed control allows for adjustment of flow from almost zero to about 1.5 gpm (0.095 L/s), which provides for sufficient pressurization of the liquid in the loop while limiting uncontrolled heating of the fluid due to the addition of pumping power. A valve between the viscometer chamber and the discharge to the test cell can be adjusted, along with the flow rate, to produce the required pump discharge pressure at a reasonable flow rate. A pressure gauge is installed at the pump discharge to monitor the pressure increase. A pressure relief valve set to open at 500 psig (3.5 MPa) is installed just downstream of the pump discharge to provide a safe release of fluid if the downstream flow is inadvertently blocked by the closing of a valve or other restriction.

The chamber that holds the viscometers is constructed from a 1.25 in. NPT (31.75 mm) stainless steel pipe cross. Each of the viscosity sensors thread into a branch of the pipe cross. The fourth branch is plugged for possible future use. Passing over an in-line RTD, which provides a check of the temperature, fluid enters the chamber through a fitting in the side of the pipe cross, flowing around the active portion of the viscosity sensors before returning to the test cell through the 0.25 in. (6.35 mm) diameter return line.

The inlet and exit lines contain valves to isolate the chamber for removal or disassembly. A vacuum/drain port is connected to the return line to allow removal of

fluid after isolation of the chamber from the test cell before disassembly and to enable the necessary evacuation of the chamber after reinstallation into the loop. The total volume of the fluid contained in this loop is 3.51 in.³ (57.5 mL), about 1.2% of the total system volume.

Sampling loop

A 4.6 in.³ (75 mL) sampling cylinder is connected in parallel with the viscometer and may be independently isolated and removed from the system for measurements of the liquid composition. The sampling loop was assembled with this cylinder and two union bonnet valves on each side, as illustrated in Figure 2.3. The outer valves may be closed to isolate the chamber from the rest of the system, and the inner valves are closed to ensure that no fluid escapes from the sampling cylinder when it is removed. A vacuum/drain port is also provided. The total volume of the sampling loop is 5.0 in.³ (82 mL). Since this is about 1.6% of the total system volume, disturbances of test cell conditions are minimized during sampling.

Equipment enclosure

Although all components of the facility are insulated, a frame and panel enclosure consisting primarily of steel framing, plywood, fiberglass ductboard, and plexiglass viewports was constructed to provide additional isolation from the room environment. This provides greater thermal uniformity and stability as well as affording a measure of protection to operators in the event of a high-pressure leak of the hot oil/refrigerant mixture. At the same time, the enclosure was designed to allow accessibility and visibility for proper operation and monitoring.

Table 2.1: Summary of instrumentation ranges and precision

Instrument	Range	Precision
Bonded Strain Gauge Pressure Transducer	0 - 500 psia (0 - 3.5 MPa)	± 0.75 psia (± 5.1 kPa)
Variable Capacitance Pressure Transducer	0 - 500 psia (0 - 3.5 MPa)	± 0.55 psia (± 3.8 kPa)
Viscometer	0.1 - 2000 cp	$\pm 2\%$ rdg.
Platinum RTD and Signal Conditioner	-50°C - +150°C (-58°F - +302°F)	± 0.1 °C (± 0.2 °F)
Copper-constantan Thermocouple	-270°C - +400°C (-455°F - +750°F)	± 0.2 °C (± 0.4 °F)
Concentration Measurements	0 - 100%	$\pm 1\%$

Data acquisition

Viscosities, temperatures, and pressures are recorded by computerized data acquisition methods. A microcomputer controls a digital multimeter and a switching unit that provides a sufficient number of channels to monitor all signals generated by the installed sensors. Table 2.1 gives a summary of the range and precision of the sensors.

A bonded strain gauge pressure transducer is in contact with the test cell contents via a port machined into the top plate. A second pressure transducer employs a capacitance-sensing element. The calibrations of these pressure transducers were checked with the use of a dead-weight pressure tester. These calibration checks indicated that the output signals of both transducers were linear with pressure, matching the factory calibrations. The uncertainty in the pressure data is ± 0.75 psi (5.2 kPa).

Three platinum RTDs independently track the temperature of the liquid contained in the test cell, and another monitors the vapor space temperature. A fifth RTD is inserted into the pipe cross containing the viscometers. These RTDs were calibrated after connection with current transmitters, the required load resistors, and a power supply. The signal conditioners used with the RTDs linearize the response, providing a 4- to 20-mA signal that is linear over the temperature range -58°F (-50°C) to 300°F (150°C). This signal produces a 1- to 5-volt output when measured across a 250-ohm load resistor, which is monitored by the data acquisition equipment. The calibration of output voltage vs. temperature showed that all of these RTDs provide a linear response. The uncertainty of these temperature measurements is $\pm 0.2^{\circ}\text{F}$ (0.1°C).

Nine type-T thermocouples are affixed to the exterior surface of the test cell, below the layer of insulation, to monitor thermal gradients in the wall. These thermocouples are connected through a switch to an electronic ice-point reference junction, and the output is monitored by the digital voltmeter. These temperature readings have an estimated uncertainty of $\pm 0.4^{\circ}\text{F}$ (0.2°C)

Description of the Oil/Refrigerant Charging Station

A charging station was designed to inject precise amounts of both refrigerant and lubricant into the test cell. As shown in Figures 2.5 and 2.6, oil and refrigerant are injected by separate, parallel systems. Both the oil and refrigerant sides employ stainless steel cylinders of 37.7 in.^3 (617.8 mL) having a 2-in. (50.8 mm) bore with a 12-in. (304.8 mm) stroke and of 4.4 in.^3 (72.4 mm) having a 0.75 in. (19.05 mm) bore and a 10-in. (254.0 mm) stroke. The cylinder displacements were calibrated

Figure 2.5: Oil/refrigerant charging facility

Figure 2.6: Oil/refrigerant charging facility schematic

with the use of R-113, and they agree with the above values to within $\pm 0.1 \text{ in.}^3$ (2 mL). The commercially available cylinders are in two different sizes to allow injection of initial and additional amounts of either oil or refrigerant in suitable quantities to give the desired concentration increments.

A 2.5 gal (9.5 L) bladder accumulator rated for a maximum pressure of 3000 psi (20.7 MPa) serves as a refrigerant reservoir for filling the cylinders on the refrigerant side. Since initial property testing is for R-22 and R-502, a butyl bladder that is compatible with both refrigerants is installed in the accumulator. However, other bladder types can be installed depending on the refrigerant being tested. Initially, the bladder of the accumulator is pressurized with nitrogen to about half the refrigerant saturation pressure. The accumulator is then partially filled with liquid refrigerant from a commercial supply can. A cooling loop wrapped around the accumulator aids the filling process by maintaining a pressure gradient between the supply can at room temperature and the accumulator at a lower temperature where any refrigerant vapor present condenses. The bladder is then further pressurized with nitrogen to ensure that only liquid refrigerant is contained in the accumulator. This pressure is also used to force refrigerant out into the injection cylinders.

The presence of a "solid" charge of subcooled liquid in the injection cylinder is checked by applying nitrogen pressure well above the vapor pressure of the refrigerant and ensuring no rod movement. The cylinder contents are then discharged to the test cell through 0.25 in. (6.35 mm) diameter lines and a connecting refrigeration hose by application of pressurized nitrogen gas to the rod side of the cylinder as the charging valve on the test cell is opened. A partial injection of a given volume can be made by determining in advance the required displacement and then moving the

rod to the appropriate position on a scale mounted directly behind the rod.

On the oil side, an oil reservoir was made from an altered 6 in. (152.4 mm) diameter by 30 in. (762 mm) long horizontal liquid receiver. The volume of this reservoir is approximately 850 in.³ (13.9 L). The oil reservoir is insulated and equipped with a heating tape, a thermocouple, and a thermostat. The contents can thus be heated as a vacuum is applied in order to liberate dissolved air and water vapor. The removal of air and water vapor from the oil is especially important prior to injection for testing. Since the vapor pressures of the naphthenic oil are very low, heating the oil to only 150°F (65°C) under a vacuum of approximately 29 in. Hg (3 kPa absolute pressure) will not remove the "light ends" of the oil. Thus, the oil properties are substantially unchanged. The unpressurized oil supply tank fills the empty, evacuated cylinders by gravity feed through 0.5 in. (12.7 mm) lines until the oil completely fills the cylinders. Again, pressurization of the rod side of the cylinder forces the lubricant through the connections to the test cell. Separate pressure gauges on each cylinder along with strategically placed pressure relief valves assist the safe operation of the system.

Summary

A versatile oil/refrigerant test facility has been developed to provide critically needed property data, especially at high pressures and temperatures, for a wide variety of oil/refrigerant mixtures. Incorporating a commercially available viscometer, as well as windows for observation of the contents, it can be used for determination of the solubility, viscosity, and density of these mixtures. Precise and convenient charging of mixtures with refrigerant compositions ranging from 0 to 100% is provided by a separate charging station. Operating temperature and pressure ranges for the

test facility are 70°F (20°C) to 300°F (150°C), and 0 to 500 psia (0 to 3.5 MPa), respectively. The viscosity measurement range is from 0.1 cp to 200 cp.

The following chapters outline the experimental methods and provide experimental results of mixtures of R-22 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene lubricant as well as mixtures of R-502 in both of these same oils.

CHAPTER 3. EXPERIMENTAL PROCEDURES AND DATA REDUCTION

In addition to, and concurrent with, the development of the test facility, procedures were developed for accurate and convenient measurement of the solubility, viscosity and density of a wide range of oil/refrigerant solutions. This chapter provides a discussion of the experimental procedures that were employed to collect the data discussed in later chapters.

General Experimental Procedures

The methods used to charge and operate the test facility vary, depending on the range of compositions and conditions desired in a particular test. A typical operating procedure for collecting viscosity and solubility data over a range of liquid-phase compositions and temperatures involves several operations. These operations, which are described in more detail later in this chapter, include evacuation of the test cell and auxiliary flow loops, injection of the necessary oil and refrigerant quantities, operating the gear pump to provide good mixing, heating the test cell and contents to the desired temperature, checking to ensure steady-state conditions, and taking the data. Prior to injecting another incremental charge to change the liquid concentration, cooling of the vessel contents to room temperature is required.

All measurements of pressure, temperature, and viscosity are done under programmed control of the data acquisition system described earlier. Careful recording of liquid level as the temperature changes allows for the calculation of liquid density at each test condition. As explained more fully below, this also permits a calculation of the actual liquid composition, which varies slightly with temperature because of variation in vapor and liquid densities.

Rig cleansing

Prior to the injection of any fluid for testing, the test cell and auxiliary loops are rinsed and cleaned with a sufficient amount of R-113 (or other solvent compatible with the O-ring material in the cell) to remove traces of any oil that had been previously tested. The O-rings that seal the windows may also be replaced at this time if a failure to hold a vacuum or set pressure indicates that this is necessary.

Data measurement

The cell and auxiliary loops are then evacuated, and the connecting hoses from the charging station are attached to a valve on the test cell. Measured amounts of refrigerant and oil are injected to provide the desired volume and concentration of liquid. The circulating pump aids mixing of the two fluids as they are charged. The contents are then heated to desired temperatures whereupon pressures, temperatures, viscosity, and height of the liquid-vapor interface are read after checking to ensure steady-state operation. The reported pressure is the average of the pressures indicated by the two transducers. This solubility pressure is reported at a liquid-vapor interface temperature, taken to be the average of the temperature of the RTD in contact with

vapor only and the average liquid temperature. The average liquid temperature is the mean of the temperatures of the RTDs immersed in liquid in the test cell and the RTD in the flow loop pipe cross containing the viscometers. The liquid density is reported at this temperature. The viscosity is reported at the temperature measured by an RTD inside the viscometer, which is generally slightly higher than the average liquid temperature due to the internal self-heating of the viscometer as discussed in Chapter 2. At each measurement point, 20 consecutive viscosity readings are recorded and the mean and standard deviation are computed. The acceptable scatter, defined as the standard deviation divided by the mean, is taken as 1% or less. Once the limiting pressure of 500 psia (3.5 MPa) is approached, the contents are allowed to cool. More data are then collected at several steady-state test points during the cooldown phase.

A special precaution is in order when testing refrigerant blends or azeotropes such as R-502. In tests with these fluids, the vapor space should be minimized to ensure that the refrigerant remains dissolved in the liquid in its azeotropic (or blended) proportions. Otherwise, given a large vapor space, the more volatile component of the azeotrope will tend to concentrate in the vapor space and the other component will be preferentially dissolved in the liquid, thus effecting a partial separation of the azeotrope into its components. In this case, the refrigerant would not be present in the liquid in its azeotropic proportions, and the compositions of both the vapor phase and the liquid phase would be unknown. In summary, if the vapor space is limited, one can more safely assume that the liquid contains the refrigerant in its azeotropic composition.

Oil/refrigerant sample evaluation

After the solubility and viscosity data for a given mixture have been collected over the desired temperature range, the sample cylinder is isolated and removed so that the mass fraction of refrigerant in the liquid can be determined. The procedure for determining the composition of an oil/refrigerant mixture by sampling is as follows:

- The full sample cylinder is weighed.
- One valve is cracked to carefully vent off the refrigerant.
- The cylinder is heated and the remaining refrigerant is evacuated.
- The chamber, now containing only oil, is weighed.
- Using a suitable solvent, the oil is removed.
- The empty chamber is weighed.
- The net weights of the oil and the mixture, as well as the refrigerant, are found by differences, and the mixture composition is calculated (to an estimated uncertainty of $\pm 1\%$).

The temperature, pressure, and liquid level at which the sample was removed are also noted. At this point oil may be injected into the test cell or refrigerant may be added (or vented) to alter the concentration for another set of data.

Mixture concentration and density determination

The actual concentration and the density of the liquid is calculated as follows for each test condition. Since the vapor mass varies along with slight variations in the volume as the temperature and pressure change, the refrigerant vapor density changes. This also means that the liquid concentration varies slightly as the temperature and pressure change. Generally, the overall variation in refrigerant concentration as temperature and pressure were changed during any particular test was less than 2%. The vapor density is calculated from temperature and pressure by a computerized property routine based on work by Reynolds (1979). However, it should be noted that any accurate property relation or table could also have been used. With this density and the vapor volume determined from the level of the vapor-liquid interface, the mass of refrigerant in the vapor is calculated. Since the total mass of oil and refrigerant charged is known, the mass of refrigerant in the liquid is calculated by subtracting the mass of the vapor from the total mass of refrigerant in the cell. A ratio of the mass of refrigerant in the liquid to the total liquid mass determines the resulting liquid composition at each test condition. As noted earlier, the liquid is also sampled at one temperature during each run to check the composition at that test condition.

With the known masses of oil and refrigerant and the observed level of the liquid, the liquid densities are calculated for each test point. It should be noted that these densities are determined from test data, and are not calculated using the ideal mixing assumption. As a point of comparison, the liquid density at the sampling temperature is also determined from the net mass of the liquid sample and the known volume of the sampling chamber.

Table 3.1: Calibration of viscosity sensor

Liquid	Temperature		Measured Value (cp)	Published Value (cp)	% Diff. ($\pm 0.5\%$)
	(°C)	(°F)			
K3 Calibration Fluid	100.0	212.0	0.892	0.878	+ 2
	86.9	188.4	1.04	1.04	0
	66.6	151.9	1.40	1.39	+ 1
	52.0	125.6	1.79	1.77	+ 1
	48.0	118.4	1.94	1.92	+ 1
K6 Calibration Fluid	110.5	230.9	1.23	1.23	0
	97.1	206.8	1.55	1.50	+ 3
	87.1	188.8	1.77	1.75	+ 1
	79.8	175.6	2.05	1.99	+ 3
	70.5	158.9	2.38	2.37	+ 0

System Calibration Check

The calibrations of the instruments were checked by running tests with pure R-22 and with two ASTM standard calibration fluids whose properties were readily available. Figure 3.1 shows that vapor pressures of pure R-22 were measured to within 0.7% of the saturation pressures published by ASHRAE (1989). The data in Table 3.1 also indicate close agreement between published viscosities and those measured by one of the viscosity sensors used in the tests reported here. Since the agreement is generally within the uncertainty band of the instrumentation, as discussed earlier, confidence in the accuracy of the results presented here is warranted.

Repeatability

Prior to more extensive studies of the oil/refrigerant pairs mandated by the monitoring committee, repeatability studies of the test facility were undertaken using mixtures of R-22 in a 150 SUS naphthenic oil. Presented here are data for nominal

Figure 3.1: R-22 vapor pressure data

approximate concentrations of 10% to 40% R-22 (by mass) in oil, over a temperature range from about 70°F (20°C) to 300°F (150°C). Figures 3.2 and 3.3 show the raw data for solubility and viscosity of each mixture composition with second order curve fits applied. The data sets for most of the compositions shown include results from at least two separate test runs involving separate refrigerant and oil charging operations. These data show good repeatability, as can be inferred from the plots. This is further highlighted in Figures 3.4 and 3.5, where the solubility and viscosity results for several repeatability test runs are plotted for an R-22 concentration of 30%.

Comparison with past work

Comparison of these experimental data with previously published work is possible over a limited range of conditions. Solubility data from the manufacturer's literature are plotted along with the experimental results for the 10% and 30% R-22 concentrations in Figure 3.6. Viscosity data for these mixtures were not available from the manufacturer. However, ASHRAE (1986) provides some limited viscosity data for 0 to 30% R-22 in a 150 SUS naphthenic oil for temperatures up to 140°F (60°C). Figure 3.7 shows a comparison of the ASHRAE data with the experimental data measured in this study for a refrigerant concentration of 30% R-22. The differences that exist are possibly due to changes in the feedstocks and processing of the oil in the years since the manufacturer's data were first generated.

Figure 3.2: Solubility data for mixtures of R-22 and a 150 SUS naphthenic oil

Figure 3.3: Viscosity data for mixtures of R-22 and a 150 SUS naphthenic oil

Figure 3.4: Test of repeatability of solubility measurements for 30% R-22 in a 150 SUS naphthenic oil

Figure 3.5: Test of repeatability of viscosity measurements for 30% R-22 in a 150 SUS naphthenic oil

Figure 3.6: Solubility data for mixtures of R-22 and a 150 SUS naphthenic oil - comparison with literature

Figure 3.6: Solubility data for mixtures of R-22 and a 150 SUS naphthenic oil - comparison with literature

Figure 3.7: Viscosity data for mixtures of R-22 and a 150 SUS naphthenic oil - comparison with literature

Data Reduction

Calculations required to determine the liquid density and composition from observed data at each test condition have been discussed in general terms in a previous section which outlined experimental procedures. A more detailed discussion of these calculations and the associated uncertainties, illustrated by using an example test condition, is provided in Appendix B.

Once the basic components of temperature, composition, pressure, liquid viscosity and density are determined for each data point, a useful and convenient presentation of the results requires the development of correlating equations. The following section presents a discussion of the techniques which were used to derive coefficients for empirical correlating equations to represent the data. Also discussed here is the so-called "Daniel" plot which provides solution property information in a particularly useful format.

Data correlation technique

After all the data have been compiled into one file, a nonlinear regression analysis is performed to determine the best set of coefficients for the following empirical equations. These equations can be used to reproduce the data or to interpolate results at intermediate states for which data were not directly obtained. It should be noted that these equations are empirical fits of the data, and are not based on theoretical considerations.

$$\begin{aligned} \log_{10} \mu = & A_0 + A_1 C + A_2 \theta + A_3 C \theta + A_4 C^2 \\ & + A_5 C^2 \theta + A_6 C \theta^2 + A_7 \theta^2 + A_8 C^2 \theta^2 \end{aligned} \quad (3.1)$$

$$P = B_0 + B_1C' + B_2\theta + B_3C'\theta + B_4C'^2 + B_5C'^2\theta + B_6C'\theta^2 + B_7\theta^2 + B_8C'^2\theta^2 \quad (3.2)$$

$$\rho_L = D_0 + D_1C' + D_2\theta + D_3C'\theta + D_4C'^2 + D_5C'^2\theta + D_6C'\theta^2 + D_7\theta^2 + D_8C'^2\theta^2 \quad (3.3)$$

where

μ = absolute viscosity, centipoise (cp),

P = the absolute pressure, MPa,

ρ_L = the density of the liquid, g/mL,

C' = the mass fraction of refrigerant in the liquid, and

θ = the temperature in K divided by

a reference temperature of 293.15K.

Though the above equations are nonlinear, they are linearized using the following variable substitutions in order to make use of a general-purpose multivariate linear regression algorithm to determine the coefficients:

$$\begin{array}{llll} X_1 = C'; & X_2 = \theta; & X_3 = C'\theta; & X_4 = C'^2; \\ X_5 = C'^2\theta; & X_6 = C'\theta^2; & X_7 = \theta^2; & X_8 = C'^2\theta^2 \end{array}$$

The resulting equations are linear in the eight variables X_1 through X_8 . For example,

$$\begin{aligned} \log_{10} \mu = & A_0 + A_1X_1 + A_2X_2 + A_3X_3 + A_4X_4 \\ & + A_5X_5 + A_6X_6 + A_7X_7 + A_8X_8 \end{aligned} \quad (3.4)$$

The regression algorithm is provided in the Fortran subroutine RGIVN available in a library of mathematical and statistical subroutines (IMSL 1989). Another of these subroutines, RSTAT, is employed to provide statistical information about the significance of each of the coefficients in the above equations, and to calculate regression coefficients as an indication of the overall goodness of fit of each equation.

“Daniel” plot

One form of the oil/refrigerant solution property data that is convenient for compressor designers is the “Daniel” plot. In a manner similar to that of Daniel et al. (1982), the figure has two parts. On the upper portion of this figure, kinematic viscosity of the oil/refrigerant solution is plotted vs. temperature for a range of refrigerant concentrations. This upper grid is identical in form to the ASTM viscosity-temperature charts, which have nonlinear scales for both kinematic viscosity and temperature. For many oils, the kinematic viscosity-temperature relationship plots as a nearly straight line on this type of chart. The equation of a straight line on this nonlinear grid is given by

$$\log(\log(\nu + 0.7)) = A + B \cdot \log T \quad (3.5)$$

where

ν = kinematic viscosity, in centistokes,

T = thermodynamic temperature, in K or °R,

and A and B are constants specific to the fluid.

In the lower part of the figure, solubility information is presented in the form of pressure vs. temperature for a range of refrigerant concentrations. Using the upper and lower parts of this figure together, the viscosity-temperature relationship can be

graphically determined for any desired pressure. This type of plot is employed several times in later chapters.

Summary

Experimental procedures for operation of the oil/refrigerant test facility have been described in detail. Data reduction techniques, including the correlation equations and the “Daniel” plot, were outlined. Data presented in this chapter show that the instrumentation is accurate and that the test results are repeatable. Thus, some confidence in the results presented in the next chapters is warranted.

CHAPTER 4. R-22 AND OIL SOLUTION PROPERTY RESULTS

This chapter presents results of solubility, viscosity, and density measurements for R-22 in a naphthenic oil and in an alkylbenzene. Graphical representations of the data and the results of the regression analysis are given. Tabulations of the actual experimental data are contained in Appendix C.

Results and Discussion

Results of the measurements with R-22 in both a 150 SUS naphthenic oil and a 150 SUS alkylbenzene oil are presented below. The naphthenic oil used for these measurements is characterized by carbon-type composition as C_A 14%, C_N 43%, C_P 43%, and has a molecular weight of approximately 300. The other lubricant was a branched alkylbenzene with an approximate molecular weight of 330. For each oil/refrigerant pair, the data set at a nominal liquid composition consists of the temperature, pressure, actual composition, absolute viscosity, and density values for a series of test points. The results are provided graphically as well as in the form of empirical correlations derived from the original test data. Results for the two oil/refrigerant pairs are compared with existing data where available. Finally, the pressure (solubility) and viscosity results for the two oil/refrigerant pairs are compared with each other.

As described in the previous chapter, the correlating equations are empirical fits of the data, and are not based on theoretical considerations. The coefficients for these correlating equations, as derived for both oil/refrigerant pairs, are given in Table 4.1. Figures 4.1 through 4.4 show that the correlations for solubility and viscosity of the R-22/oil solutions are well fit to the test data, generally within $\pm 5\%$. Plots showing goodness-of-fit for the density correlations are not given because the fits were well within $\pm 1\%$. It should be noted that, when using the correlations in lieu of the graphs, care must be taken to avoid extrapolation beyond the limits of applicability given along with the coefficients in Table 4.1.

R-22/Naphthenic Oil Solutions

Results for the solubility of R-22 in a 150 SUS naphthenic oil for solutions of 0 to 40 weight percent R-22 are given in Figure 4.5. This figure, which is a plot of pressure vs. refrigerant concentration for a range of temperatures, shows that the pressure increases with increasing refrigerant concentration and temperature.

Figure 4.6 provides the results of the correlation equation for absolute viscosity as a function of temperature and refrigerant mass fraction. Note that this semilogarithmic graph is different from an ASTM chart where kinematic viscosity is plotted vs. temperature on non-linear axes, according to Equation 3.5. The temperature range is from 104°F (40°C) to 302°F (150°C), well beyond the temperature range of viscosity data reported in the existing literature. Similarly, the results for the mixture density are given in Figure 4.7. In this figure, the curves for the specified compositions are truncated at various temperatures. These endpoints are approximately the

Table 4.1: Coefficients for Empirical Correlations of Viscosity, Pressure, and Density Data for R-22/oil Solutions

R-22/150 SUS Naphthenic Oil Correlations			
Term	Viscosity (Eq. 3.1)	Pressure (Eq. 3.2)	Density (Eq. 3.3)
Intercept	$A_0 = 12.064$	$B_0 = 0.0000$	$D_0 = 0.9680$
C	$A_1 = -23.115$	$B_1 = -40.624$	$D_1 = 8.0012$
θ	$A_2 = -15.034$	$B_2 = 0.0000$	$D_2 = 0.0000$
$C\theta$	$A_3 = 29.756$	$B_3 = 44.437$	$D_3 = -12.329$
C^2	$A_4 = 0.0000$	$B_4 = 336.20$	$D_4 = -37.574$
$C^2\theta$	$A_5 = 0.0000$	$B_5 = -572.75$	$D_5 = 63.512$
$C\theta^2$	$A_6 = -10.937$	$B_6 = 0.0000$	$D_6 = 5.1303$
θ^2	$A_7 = 4.7125$	$B_7 = 0.0000$	$D_7 = -0.07068$
$C^2\theta^2$	$A_8 = 1.8135$	$B_8 = 233.87$	$D_8 = -27.448$

R-22/150 SUS Alkylbenzene Correlations			
Term	Viscosity (Eq. 3.1)	Pressure (Eq. 3.2)	Density (Eq. 3.3)
Intercept	$A_0 = 11.838$	$B_0 = 0.0000$	$D_0 = 0.9425$
C	$A_1 = -25.046$	$B_1 = -39.913$	$D_1 = 4.8540$
θ	$A_2 = -14.821$	$B_2 = 0.0000$	$D_2 = 0.0000$
$C\theta$	$A_3 = 30.781$	$B_3 = 40.523$	$D_3 = -7.7083$
C^2	$A_4 = 7.5077$	$B_4 = 254.81$	$D_4 = -18.812$
$C^2\theta$	$A_5 = -5.2574$	$B_5 = -425.86$	$D_5 = 33.075$
$C\theta^2$	$A_6 = -10.232$	$B_6 = 0.0000$	$D_6 = 3.2031$
θ^2	$A_7 = 4.6660$	$B_7 = 0.0000$	$D_7 = -0.07654$
$C^2\theta^2$	$A_8 = 0.0000$	$B_8 = 172.55$	$D_8 = -14.431$

Note: The limits of applicability of the correlations are:

Composition - 0 to 40 weight percent Refrigerant-22

Temperature - 40°C to 150°C (100°F to 300°F)

(θ : 1.07 to 1.44)

Pressure - 0 to 3.5 MPa (0 to 500 psia)

Figure 4.1: Goodness-of-fit of pressure correlation with experimental data for solutions of R-22 in a 150 SUS naphthenic oil

Figure 4.2: Goodness-of-fit of viscosity correlation with experimental data for solutions of R-22 in a 150 SUS naphthenic oil

Figure 4.3: Goodness-of-fit of pressure correlation with experimental data for solutions of R-22 in a 150 SUS alkylbenzene

Figure 4.4: Goodness-of-fit of viscosity correlation with experimental data for solutions of R-22 in a 150 SUS alkylbenzene

Figure 4.5: Solubility of R-22 in a 150 SUS naphthenic oil

Figure 4.6: Absolute viscosity of R-22 in a 150 SUS naphthenic oil

Figure 4.7: Density of R-22 in a 150 SUS naphthenic oil

points beyond which the correlation is no longer expected to be applicable, and correspond roughly to test conditions at which the pressure approached the maximum limit.

Figure 4.8 is a "Daniel" plot which provides kinematic viscosity information for these solutions in a form convenient for designers. As explained in Chapter 3, the figure has two parts. On the upper portion of this figure, kinematic viscosity of the oil/refrigerant solution is plotted vs. temperature for a range of refrigerant concentrations. Since kinematic viscosity is equal to the absolute viscosity divided by the density, this upper graph is actually a derivation from the basic information in Figures 4.6 and 4.7. In the lower part of Figure 4.8, the solubility information of Figure 4.5 is recast in the form of pressure vs. temperature for a range of refrigerant concentrations. Several constant-pressure curves of viscosity vs. temperature are provided in this figure. (The curves shown have been computed from the correlations, rather than by graphical derivation.)

The upper part of Figure 4.8 shows that as temperature and refrigerant concentration increase, the viscosity of the solution decreases. The constant concentration lines have some curvature, especially at the higher temperatures. By comparison, similar curves on ASTM viscosity plots at lower temperatures are somewhat more linear. For a given pressure, viscosity initially increases and then decreases as temperature increases. The cause of this behavior is the decrease in the concentration of refrigerant in the oil as temperature increases, thus lessening the viscosity reduction caused by the refrigerant. However, the viscosity of the oil also decreases as temperature increases, and this effect eventually overcomes the earlier effect that had caused the viscosity to increase.

Figure 4.8: Viscosity-temperature-pressure chart for solutions of R-22 in a 150 SUS naphthenic oil

Comparison with solubility data in the manufacturer's literature shows that the current experimental data and the associated correlation give pressures that are somewhat higher than those reported by the manufacturer (see Figure 4.9). Discussions with experienced users of these lubricants indicate that differences are to be expected due to the variability inherent in the oil due to processing changes that have been made over the years. No viscosity data for R-22 solutions in this particular oil were readily available from the existing literature for comparison with the experimental data reported here.

R-22/Alkylbenzene Solutions

The presentation of the results for solutions of R-22 in a 150 SUS alkylbenzene is similar to that of the previous section for a naphthenic oil. Figures 4.10, 4.11, and 4.12 provide the solubility, absolute viscosity, and density data, respectively. Figure 4.13 provides the kinematic viscosity and solubility combined in a form convenient to designers. Again, especially for viscosity, the data presented here extend the temperature range well beyond that of any data previously available. As previously noted, the curvature seen in the curves compared to ASTM viscosity charts may be due to the fact that higher temperatures are being investigated.

Figure 4.14 gives a comparison of test results with solubility data reported by Glova (1984) for a similar alkylbenzene. It appears that the presently reported pressures are somewhat higher. Figure 31 of Chapter 8 in ASHRAE (1990) provides an estimate of the viscosity- temperature-pressure relationship for solutions of R-22 in a 150 SUS alkylbenzene for temperatures up to 60°C (140°F). Since the present test data begin at 100°F (38°C), a comparison with estimated values is possible over the

Figure 4.9: Correlation of test results compared with manufacturer's solubility data for solutions of R-22 in a 150 SUS naphthenic oil

Figure 4.10: Solubility of R-22 in a 150 SUS alkylbenzene

Figure 4.11: Absolute viscosity of R-22 in a 150 SUS alkylbenzene

Figure 4.12: Density of R-22 in a 150 SUS alkylbenzene

Figure 4.13: Viscosity-temperature-pressure chart for solutions of R-22 in a 150 SUS alkylbenzene

Figure 4.14: Correlation of test results compared with previously reported solubility data for solutions of R-22 in a 150 SUS alkylbenzene

limited range of 38°C to 60°C (100°F to 140°F). Figure 4.15 shows that very good agreement is indicated.

Comparison of R-22/Naphthenic Oil and R-22/Alkylbenzene Results

With the above data, it is possible to compare the solubility and viscosity of R-22 in solutions with naphthenic oil and with alkylbenzene. Figure 4.16 is an overlay of selected solubility data from Figures 4.5 and 4.10. Figure 4.17 compares absolute viscosities as correlated for two representative concentrations. They show that the R-22/150 SUS alkylbenzene solutions have lower pressures and generally lower absolute viscosities than do the R-22/150 SUS naphthenic oil solutions at a specified temperature and composition.

Summary

Data for solutions of R-22 in both a 150 SUS naphthenic oil and a 150 SUS alkylbenzene oil have been collected. These tests greatly extend the temperature range of previously available data for these two oil/refrigerant pairs, providing solubility and viscosity information for temperatures as high as 300°F (149°C). The results are presented as solubility, viscosity, and density charts that give pressure, liquid viscosity, and liquid density, respectively, as functions of temperature and refrigerant concentration. Empirical correlating equations (applicable only over the range of data collected) that allow convenient interpolation of the data are also provided.

Figure 4.15: Correlation of test results compared with estimates of viscosity data for solutions of R-22 in a 150 SUS alkylbenzene

Figure 4.16: Comparison of the solubility of R-22 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene

Figure 4.17: Comparison of the viscosity of R-22 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene

CHAPTER 5. R-502 AND OIL SOLUTION PROPERTY RESULTS

Solubility and viscosity data for solutions of R-502 with the same two lubricants used with the R-22 were also collected. This data is significant for design, and also for proving the methodology developed in this research project. Specifically, R-502 and the two lubricant combinations have miscibility characteristics similar to those expected of some alternative refrigerant/oil pairs that are of current interest because of the CFC issue.

This chapter presents results of measurements for R-502 in a naphthenic oil and in an alkylbenzene using the equipment described in Chapter 2. Results for the two oil-refrigerant pairs are compared with existing data where available. The pressure (solubility) and viscosity results for the two oil-refrigerant pairs are compared with each other. In a manner similar to that done for the R-22/oil mixtures, the coefficients of correlating equations were determined by the nonlinear regression analysis described in Chapter 3 for the solubility (pressure), viscosity, and density of these solutions. These coefficients, as well as graphical representations of the data, are given here. Tabulations of the actual experimental data are provided in Appendix C.

Results and Discussion

Results of the measurements with R-502 in both a 150 SUS naphthenic oil and a 150 SUS alkylbenzene oil are presented below. The lubricants used in these tests were samples drawn from the same lots that were used in the R-22/oil studies discussed in Chapter 4. The reader will recall that the naphthenic oil is characterized by carbon-type composition as C_A 14%, C_V 43%, C_P 43%, and has a molecular weight of approximately 300. The other lubricant was a branched alkylbenzene with an approximate molecular weight of 330.

The data set for each oil-refrigerant pair includes temperature, pressure, actual composition, absolute viscosity, and density for a range of conditions. The results are provided graphically as well as in the form of empirical correlations derived from the original test data. These equations are empirical fits of the data, as pointed out in Chapter 3, and are not based on theoretical considerations. The coefficients for these correlating equations, as derived for both R-502/oil pairs, are given in Table 5.1.

Figures 5.1 through 5.4 show that these correlations for solubility and viscosity of both R-502/oil solutions are well fit to the test data, generally within $\pm 5\%$. Since the density correlations fit the data to well within $\pm 1\%$, goodness-of-fit plots for density are not given. Again, it should be noted that, when using the correlations in lieu of the graphs, care must be taken to avoid extrapolation beyond the limits of applicability given along with the coefficients in Table 5.1.

Table 5.1: Coefficients for empirical correlations of viscosity, pressure, and density data for R-502/oil solutions

R-502/150 SUS Naphthenic Oil Correlations

Term	Viscosity (Eq. 3.1)	Pressure (Eq. 3.2)	Density (Eq. 3.3)
Intercept	$A_0 = 10.001$	$B_0 = 0.0000$	$D_0 = 1.0625$
C	$A_1 = -2.7139$	$B_1 = 0.0000$	$D_1 = 0.0000$
θ	$A_2 = -11.948$	$B_2 = 0.0000$	$D_2 = -0.1666$
$C\theta$	$A_3 = 0.0000$	$B_3 = -19.941$	$D_3 = 1.2755$
C^2	$A_4 = 73.854$	$B_4 = 115.36$	$D_4 = 0.0000$
$C^2\theta$	$A_5 = -138.60$	$B_5 = -229.38$	$D_5 = -1.0761$
$C\theta^2$	$A_6 = 0.0000$	$B_6 = 26.173$	$D_6 = -0.6283$
θ^2	$A_7 = 3.5653$	$B_7 = 0.0000$	$D_7 = 0.0000$
$C^2\theta^2$	$A_8 = 65.139$	$B_8 = 103.33$	$D_8 = 0.0000$

R-502/150 SUS Alkylbenzene Correlations

Term	Viscosity (Eq. 3.1)	Pressure (Eq. 3.2)	Density (Eq. 3.3)
Intercept	$A_0 = 11.450$	$B_0 = 0.0000$	$D_0 = 1.0640$
C	$A_1 = -6.6680$	$B_1 = 0.0000$	$D_1 = 0.4026$
θ	$A_2 = -14.194$	$B_2 = 0.0000$	$D_2 = -0.1957$
$C\theta$	$A_3 = 3.3853$	$B_3 = -20.904$	$D_3 = 0.0000$
C^2	$A_4 = 0.0000$	$B_4 = 0.0000$	$D_4 = 0.0000$
$C^2\theta$	$A_5 = 0.0000$	$B_5 = 0.0000$	$D_5 = 0.0000$
$C\theta^2$	$A_6 = 0.0000$	$B_6 = 25.006$	$D_6 = 0.0000$
θ^2	$A_7 = 4.4120$	$B_7 = 0.0000$	$D_7 = 0.0000$
$C^2\theta^2$	$A_8 = 0.9122$	$B_8 = -5.8174$	$D_8 = -0.1865$

Note: The limits of applicability of the correlations are:

- Composition - 0 to 30 weight percent R-502 in naphthenic oil
 0 to 40 weight percent R-502 in alkylbenzene
- Temperature - 40°C to 150°C (100°F to 300°F)
 (θ : 1.07 to 1.44)
- Pressure - 0 to 3.5 MPa (0 to 500 psia)

Figure 5.1: Goodness-of-fit of pressure correlation with experimental data for solutions of R-502 in a 150 SUS naphthenic oil

Figure 5.2: Goodness-of-fit of viscosity correlation with experimental data for solutions of R-502 in a 150 SUS naphthenic oil

Figure 5.3: Goodness-of-fit of pressure correlation with experimental data for solutions of R-502 in a 150 SUS alkylbenzene

Figure 5.4: Goodness-of-fit of viscosity correlation with experimental data for solutions of R-502 in a 150 SUS alkylbenzene

R-502/Naphthenic Oil Solutions

Results for the solubility of R-502 in a 150 SUS naphthenic oil for solutions of 0 to 30 weight percent R-502 are given in Figure 5.5. Absolute viscosity and density results are shown in Figures 5.6 and 5.7. The trends illustrated in these figures appear to be similar to those for the R-22/oil pairs previously discussed.

However, in contrast to the R-22 results, immiscibility was observed for higher concentrations of R-502 in solution with the naphthenic oil. This behavior is consistent with the critical solubility temperature data provided in Figure 7, Chapter 8 of the Refrigeration Systems Handbook (ASHRAE, 1990). At a nominal overall composition of 45% of R-502, two clearly observable liquid phases were present at all temperatures in the test. One of these was an oil-rich, lower-density liquid. The other liquid phase was comparatively refrigerant-rich, less viscous, and of a higher density. The upper, less dense liquid phase was apparently quite viscous, since vigorous circulation of the lower, denser liquid phase by pumping had little observable effect on the motion of the interface between the phases. It is possible that at higher temperatures a return to miscibility might occur; however, these conditions were not achievable without exceeding 500 psia (3.45 MPa), the maximum pressure limitations of the test cell.

The detection of immiscibility, if present, is one of the tests required of the measurement methodology developed in this project. The current configuration of the test facility, with windows installed on each side of the test cell, makes visual observation of immiscibility very convenient. However, further modifications would have to be made to the test cell in order to be able to independently sample each of two liquid phases for determination of viscosity and density. For this reason, viscosity

Figure 5.5: Solubility of R-502 in a 150 SUS naphthenic oil

Figure 5.6: Absolute viscosity of R-502 in a 150 SUS naphthenic oil

Figure 5.7: Density of R-502 in a 150 SUS naphthenic oil

and density data recorded during tests with the two liquid phases present are not given here. The results presented here are for a range of test conditions in which only a single liquid phase exists in equilibrium with the vapor above it.

Figure 5.8 is the two-part "Daniel-type" plot for the same solutions from 100°F (38°C) to 300°F (149°C). This plot is similar to those shown in Chapter 4, and it provides a useful form of the kinematic viscosity and solubility information.

A comparison of test results with solubility data reported by the manufacturer is given in Figure 5.9. As with the R-22 results, some differences can be explained by variability in the oil as a result of processing changes over time. No comparable viscosity data for this oil/refrigerant pair were available.

R-502/Alkylbenzene Solutions

The presentation of the results for solutions of R-502 in a 150 SUS alkylbenzene is similar to that of the previous chapter in which the HCFC-22 results are discussed. The R-502 was miscible with the alkylbenzene at all four liquid compositions studied. Figures 5.10, 5.11, and 5.12 present the solubility, absolute viscosity, and density data. Again, a "Daniel" plot (Figure 5.13) provides the viscosity and solubility combined in a useful form. The data presented here extends the temperature range of the viscosity data well beyond that of any data previously available.

Figure 5.14 gives a comparison of test results with solubility data reported by Glova (1984) for a similar alkylbenzene. It appears that the presently reported pressures are somewhat higher.

Figure 5.8: Viscosity-temperature-pressure chart for solutions of R-502 in a 150 SUS naphthenic oil

Figure 5.9: Correlation of test results compared with manufacturer's solubility data for solutions of R-502 in a 150 SUS naphthenic oil

Figure 5.10: Solubility of R-502 in a 150 SUS alkylbenzene

Figure 5.11: Absolute viscosity of R-502 in a 150 SUS alkylbenzene

Figure 5.12: Density of R-502 in a 150 SUS alkylbenzene

Figure 5.13: Viscosity-temperature-pressure chart for solutions of R-502 in a 150 SUS alkylbenzene

Figure 5.14: Correlation of test results compared with previously reported solubility data for solutions of R-502 in a 150 SUS alkylbenzene

Comparison of R-502/Naphthenic Oil and R-502/Alkylbenzene Results

With the above data, it is possible to compare the behavior and properties of R-502 in solutions with naphthenic oil and with alkylbenzene. Figure 5.15 is an overlay of selected data from Figures 5.5 and 5.10. Similarly, Figure 5.16 compares absolute viscosities as correlated for two representative concentrations. They show that the R-502/alkylbenzene solutions have lower pressures than do the R-502/naphthenic oil solutions at a specified temperature and composition. At a given concentration, the absolute viscosities of these mixtures appear to be quite similar.

However, as discussed previously, the major difference in the properties of the two solutions is the immiscibility evidenced by R-502/naphthenic oil solutions.

Summary

Data for solutions of R-502 in both a 150 SUS naphthenic oil and a 150 SUS alkylbenzene oil have been collected by using a newly developed test facility. These tests extend the temperature range of previously available data for these two oil/refrigerant pairs, providing solubility, viscosity, and density information for temperatures as high as 300°F (149°C). The immiscibility expected of R-502/naphthenic oil solutions at higher refrigerant concentrations was successfully observed.

Figure 5.15: Comparison of the solubility of R-502 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene

Figure 5.16: Comparison of the viscosity of R-502 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene

CHAPTER 6. CONCLUSIONS AND RECOMMENDATIONS

A versatile oil/refrigerant test facility has been developed to provide critically needed property data, especially at high pressures and temperatures, for a wide variety of oil/refrigerant mixtures. Incorporating a commercially available viscometer, as well as windows for observation of the contents, it can be used for determination of the solubility, viscosity, density, and miscibility of these mixtures. Precise and convenient charging of mixtures with refrigerant compositions ranging from 0 to 100% is provided by a separate charging station. Operating temperature and pressure ranges for the test facility are 70°F (20°C) to 300°F (150°C), and 0 to 500 psia (0 to 3.5 MPa), respectively. The viscosity measurement range is from 0.1 cp to 200 cp, but this range may be readily extended, if necessary.

Experimental procedures for operation of the oil-refrigerant test facility have been described. Data reduction techniques, including the correlation equations and the "Daniel" plot, were outlined. Data have been presented which show that the instrumentation is accurate and that the test results are repeatable. The procedures have been successfully employed to obtain and present experimental results for mixtures of R-22 in a 150 SUS naphthenic oil and in a 150 SUS alkylbenzene lubricant as well as for mixtures of R-502 in both of these same oils.

Data for solutions of R-22 in both a 150 SUS naphthenic oil and a 150 SUS alkyl-

benzene have been collected. These tests greatly extend the temperature range of previously available data for these two oil/refrigerant pairs, providing solubility and viscosity information for temperatures as high as 300 °F (149 °C) and for refrigerant mass fractions from 0 to 40%, subject to a maximum pressure limitation of 500 psia (3.45 MPa). The results are presented as solubility, viscosity, and density charts that give pressure, liquid viscosity, and liquid density, respectively, as functions of temperature and refrigerant concentration. Empirical correlating equations (applicable only over the range of data collected) that allow convenient interpolation of the data are also provided.

Data for solutions of R-502 in both a 150 SUS naphthenic oil and a 150 SUS alkylbenzene oil have been collected over an extended range of test conditions similar to those discussed above for R-22. The high temperature immiscibility expected of R-502/naphthenic oil solutions at refrigerant mass fractions greater than 30% was successfully observed. The solubility, viscosity, and density results for these solutions is presented in a manner similar to that of the R-22/oils results.

Recommendations for Future Work

As a result of the experience gained in the design and operation of the test facility, as well as in the data collection and correlation methods, several changes with the potential to improve and streamline the overall experimental operation have been envisioned. Recommendations for design modifications, procedural changes, and additional instrumentation are discussed below.

- Installation of an in-line densitometer in the auxiliary flow loop to eliminate the current need to use liquid volume and mass to calculate liquid density.

Several manufacturers supply electronic mass flow meters that also provide an indication of density.

- Direct sampling of the liquid at each test condition may be desirable. As a review of the detailed calculations in Appendix B would show, this would eliminate the need to measure the height of the liquid-vapor interface which gives the vapor volume and, indirectly, the refrigerant concentration in the liquid. However, the sample mass should be small compared to the overall liquid mass, so that liquid compositions are not too greatly affected by the sampling process.
- Installation of a gas chromatograph would allow analysis of the vapor. Such an analysis would be useful in the study of solutions of azeotropes and/or blends in oils, especially if immiscibility is detected.
- Modifications in the design of the test cell to permit visibility of the lowest point in the volume of liquid, so that the presence of even a small amount of a second liquid phase indicating immiscibility does not go undetected. Extra well-placed sampling ports would prove useful in determining the different refrigerant concentrations of each phase.
- Though earlier problems with seals have been solved with the current in-house design and manufacture of the windows and the proper choice of the necessary O-ring materials, others choosing to build a similar test facility may find commercially available pressure sight glasses to be more convenient to procure. In either case, the compatibility of any sealing materials with the intended test fluids must be investigated prior to purchase.

BIBLIOGRAPHY

- ASHRAE. 1986. ASHRAE handbook – 1986 Refrigeration Systems, Chap. 8. Atlanta: American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.
- ASHRAE. 1989. ASHRAE handbook – 1989 Fundamentals, Chap. 17. Atlanta: American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.
- ASHRAE. 1990. ASHRAE handbook – 1990 Refrigeration Systems, Chap. 8. Atlanta: American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.
- Baustian, J. J., M. B. Pate, and A. E. Bergles. 1988. "Measuring the concentration of a flowing oil-refrigerant mixture with a bypass viscometer." ASHRAE Transactions, Vol. 94, Pt. 2, pp. 588-600.
- CAS. 1989. Cambridge Applied Systems viscosity-temperature sensor operations manual. Cambridge, MA: Cambridge Applied Systems, Inc.
- Daniel, G., M.J. Anderson, W. Schmid, and M. Tokumitsu. 1982. "Performance of selected synthetic lubricants in industrial heat pumps." International Symposium on the Industrial Application of Heat Pumps, University of Warwick, U.K.
- Glova, D.J. 1984. "High-temperature solubility of refrigerants in lubricating oil." ASHRAE Transactions, Vol. 90, Pt. 2B, pp. 806-825.
- Holman, J.P. 1984. Experimental methods for engineers. Chap.3. New York: McGraw-Hill, Inc.

- IMSL. 1989. IMSL stat/library. Houston, TX: IMSL, Inc.
- Kline, S.J., and F.A. McClintock. 1953. "Describing uncertainties in single sample experiments." Mechanical Engineering, Vol. 75, pp.3-8.
- Reynolds, W.C. 1979. Thermodynamic properties in SI; graphs, tables, and computational equations for forty substances. Stanford, CA: Department of Mechanical Engineering, Stanford University.
- Spauchus, H. O., and L. M. Speaker. 1987. "A review of viscosity data for oil-refrigerant solutions." ASHRAE Transactions, Vol. 93, Pt. 2. pp. 667-681.
- Van Gaalen, N.A., M.B. Pate, and S.C. Zoz. 1990. "The measurement of solubility and viscosity of oil/refrigerant mixtures at high pressures and temperatures: Test facility and initial results for R-22/naphthenic oil mixtures." ASHRAE Transactions, Vol. 96, Pt. 2, pp. 183-190.
- Van Gaalen, N.A., S.C. Zoz, and M.B. Pate. 1991. "The solubility and viscosity of solutions of HCFC-22 in a naphthenic oil and in an alkylbenzene at high pressures and temperatures." ASHRAE Transactions, Vol. 97, Pt. 1, pp. 100-108.
- Van Gaalen, N.A., S.C. Zoz, and M.B. Pate. 1991. "The solubility and viscosity of solutions of R-502 in a naphthenic oil and in an alkylbenzene at high pressures and temperatures." ASHRAE Transactions, Vol. 97, Pt. 2, (to be published).

APPENDIX A. TEST FACILITY CONSTRUCTION DETAILS

This appendix provides details of the construction of some elements of the test facility and lists the suppliers and approximate costs of the components which were procured. The schematic drawings given in Chapter 2, along with the drawings and lists of components given here, provide sufficient information for those who may wish to assemble a similar facility at another site. Additionally, Chapter 6 discusses certain recommendations that, if adopted, would result in modifications to the test facility and, hence, to the information presented here and in Chapter 2.

Detailed construction information for the test cell is presented in the Figures A.1 through A.3, which are working drawings of the cell and its components as manufactured "in-house" at the I.S.U. Engineering Research Institute Machine Shop. Figure A.1 is a drawing of the basic structure of the pressure vessel, providing design details sufficient to build the test cell except for the windows. Figures A.2 and A.3 together provide manufacturing details for the components of the windows and their assembly with the test cell.

DISCLAIMER: Because these drawings illustrate the details of manufacture for the test cell after several necessary design changes were implemented, some relaxation of traditional pressure vessel safety margins has occurred. It is highly recommended that a full review of the design details occur prior to construction of any new test cell

based on these plans, and that the cell be hydrostatically tested. ASME code requires that unfired pressure vessels of this type be hydrostatically tested to at least 150% of the maximum working pressure. The current test cell has been hydrostatically tested to 650 psia and was never operated above 520 psia, and then only to test the pressure relief valve. Typically, the maximum pressure experienced in the tests reported here was 475 psia.

Suppliers and approximate costs for the components of the oil/refrigerant test facility and for the oil/refrigerant charging station are outlined in Tables A.1 and A.2, respectively. These tables, along with diagrams and discussion provided in Chapter 2, provide the information needed to construct similar equipment, without constraining the arrangement of the components in unintended ways with detailed assembly drawings of all the fittings and supporting structures. The approximate total cost of the components listed is \$ 36,000.00.

The overall project costs involve not only the component costs, but also the costs of labor to design, order, and construct the test facility. Since labor costs vary between institutions, they are not estimated here. Instead an estimate of labor time is provided so that labor costs may be determined from it by application of the appropriate wage and overhead rates. It is anticipated that given the information presented here, further design and the necessary construction to complete the facility would take six to eight person-months. Continued operation of the facility, including data reduction and analysis, on a daily basis would require the equivalent of a full time staff position.

Figure A.1: Working drawing of pressure vessel

PRESSURE VESSEL

7	2	O-RING	PARKER 2-249 V747-75
6	1	VESEL BOTTOM	FABRICATED
5	1	VESEL BODY	FABRICATED
4	1	VESEL LID	FABRICATED
3	1	RELIEF VALVE	NUPRO SS-4CPA-350
2	16	FLAT WASHER	1/2 NOMINAL ID STAINLESS
1	16	SOC HEAD CAP SCR	1/2-13 NC 1.75 STAINLESS
NO	QTY	DESCRIPTION	SPECIFICATION
IOWA STATE UNIVERSITY DEPT. OF MECHANICAL ENGINEERING ENGINEERING RESEARCH INSTITUTE			
SCALE: 1" = 2.5"			
ORIGINAL ERI DRAWINGS BY M. BRAUN 11/88			
REVISED BY N. VAN GALEN AND R. BISHOP 3/91			

2	2	SLOTTED FLATHEAD SCREW STAINLESS	8-32 X .250
1	4	CAP SCREW STAINLESS	10-32 X 1.400
NO	QTY	DESCRIPTION	SPECIFICATION
IOWA STATE UNIVERSITY DEPT. OF MECHANICAL ENGINEERING ENGINEERING RESEARCH INSTITUTE			
SCALE: 1" = 2.5"			
ORIGINAL ERI DRAWINGS BY M. BRAUN 11/88			
REVISED BY N. VAN GALEN AND R. BISHOP 3/91			

WINDOW FRAME DETAILS

O-RING GROOVE
WIDTH .160 $\pm$.002
DEPTH .104 $\pm$.002
PARKER SEALS V747-75 271

Figure A.2: Window frame details

O-RING GROOVE
DTH .180 $\pm$.002
PTH .104 $\pm$.002
ARKER SEALS V747-75 271

O-RING GROOVE
WIDTH .090 $\pm$.002
DEPTH .058 $\pm$.002
APPLE RUBBER PRODUCTS
CUSTOM O-RING

WINDOW ASSEMBLY DETAIL

9	2	RETAINING PLATE STAINLESS	13.573 X 1.374 X .125
8	2	O-RING	APPLEB.021 ID X .070
7	2	O-RING	PARKER 2-271
6	30	CAP SCREW STAINLESS	10-32 X 1.850
5	6	CAP SCREW STAINLESS	10-32 X 1.00
4	2	WINDOW QUARTZ	.75 X 1.00 X 12.35
3	6	FLAT STAINLESS	.50 X 1.50 X 5.00
2	2	PLATE STAINLESS	1.50 X 4.00 X 15.00
1	1	PIPE STAINLESS	EXISTING VESSEL
NO	QTY	DESCRIPTION	SPECIFICATION

IOWA STATE UNIVERSITY DEPT. OF MECHANICAL ENGINEERING
ENGINEERING RESEARCH INSTITUTE

SCALE: 1" = 2.5"

ORIGINAL ERI DRAWINGS BY M. BRAUN 11/88

REVISED BY N. VAN GAALEN AND R. BISHOP 3/91

Figure A.3: Window assembly details

Table A.1: List of test facility components

Item (Manufacturer & Model No., if appl.)	Appr. Cost	Qty
Test Cell (I.S.U. Engineering Research Institute Machine Shop)	\$15000.00	1
Windows		
-steel "frames" w/ slots, O-ring grooves, and screws (I.S.U. E.R.I. Machine Shop)	\$ 1000.00	2
-quartz plates, 12.35"x 1.000"x 0.75" (Wale Apparatus)	160.00	2
-O-rings, viton or neoprene, 1/8" diameter (Parker; size 2-271; V747-75 or C873-70)	4.00	2
-O-rings, viton or neoprene, 8.021"I.D. x 0.070" dia. (Apple Rubber Products)	15.00	2
-metal rule (Oregon Rule; Model EW 048L)	4.50	2
Pump assembly	\$ 975.00	1
-3 gear pump, w/ Ryton gears, magnetically driven (Micropump; Model 211/56C)		
-1/2 hp motor, TEFC, 56C face, 90 VDC, 2500 RPM max. (Leeson; Model C4D28FK1C)		
-speed controller (Minarik; Model PCM23401A)		
Viscometer		
-piston viscosity sensor (Cambridge Applied Systems; Model SPL300)	\$ 1200.00	3
-circuit card with sensing and drive electronics (C.A.S.; Model CCP300)	1200.00	2
-pipe cross and plug, 1.25" NPT stainless, 3000 psi (Central States Industrial Supply)	165.00	tot
Circulating Bath (Haake; Model N3B)	\$ 4000.00	1
-low volatility heating fluid, 6 gallons (CPI Engineering; CP-4604-15-F)	donated	1

Table A.1 (Continued)

Item (Manufacturer & Model No., if appl.)	Appr. Cost	Qty
Temperature Measuring Devices		
-platinum RTD, varying probe lengths, each matched with a signal conditioner and calibrated (HY-CAL Engineering; Model RTS-34-T-100)	\$ 150.00	5
-signal conditioner / current transmitter (HY-CAL Engineering; Model CT-801A)	115.00	5
-15 V.D.C. power supply	available	1
-type T thermocouple, fast response, self-adhesive (Omega; Model SA1-T)	12.00	10
-type T thermocouple; subminiature, 6" x 1/16" dia. (Omega; Model TMQSS-062G-6)	24.00	8
-electronic ice point reference (Omega; Model MCJ-T)	99.00	1
Pressure Transducers		
-bonded strain gage transducer, 0 to 500 psia (Viatran; Model 104S65)	\$ 900.00	1
-10 V.D.C. power supply	available	1
-capacitance sensing transducer, 0 to 500 psia (Setra Systems; Model 280E)	230.00	1
-24 V.D.C power supply (Setra Systems; Model 204970)	25.00	1
Data Acquisition Equipment		
- multimeter (Hewlett-Packard; Model 3457A)	available	1
- switch/control unit (Hewlett-Packard; Model 3488A)	available	1
- microcomputer w/ IEEE-488 bus (Digital Equipment; Pro-380)	available	1

Table A.1 (Continued)

Item (Manufacturer & Model No., if appl.)	Appr. Cost	Qty
Sample Cylinders		
-cylinder, stainless steel, 75 mL nom. size (Whitey; Model 304L-HDF4-75CC)	\$ 52.00	3
-union bonnet valve, two per sample cylinder (Whitey; Model SS-1RM4-S4)	36.00	6
Filter		
-tee type removable filter w/ 140 micron stainless steel mesh strainer (Nupro; Model SS-4TF-F2-140)	\$ 82.00	1
Miscellaneous Valves		
-union bonnet valve (Whitey; SS-1RS4)	\$ 38.00	12
-adjustable pressure relief valve (Nupro; Model SS-4CPA2-350)	26.00	2
-ball valves for temperature control loop (Apollo; Model #70-104-01)	7.00	6
Miscellaneous Fittings		
-unions, tees, and various adapters in tube diameters of 1/8", 1/4", and 1/2" (Swagelok)	\$ 500.00	tot
Insulation and Enclosure		
-steel frame, 60 feet (Unistrut; Model P1000	\$ 75.00	tot
-assembly hardware (Unistrut; P1000 series	100.00	tot
-plywood sheet (4' x 8' x 3/4")	25.00	2
-fiber glass insulation panel (4' x 8' x 1")	50.00	1
-fiber glass pipe insulation (8"ID x 1" x 3')	10.00	1
- " " " " (10"ID x 1" x 3')	13.00	1
-paint, implement enamel, 1 gallon	11.00	1

Table A.2: List of charging station components

Item (Manufacturer & Model No., if appl.)	Appr. Cost	Qty
Accumulator		
-2.5 gal. accumulator with butyl bladder (Oil-Air; Model 2.5-100-2-B)	\$ 630.00	1
-charging head assembly (Oil-Air; Model CG-3013)	65.00	1
Oil reservoirs		
-modified horizontal receiver (Standard Refrigeration; Model 306 - with modified fittings)	\$ 160.00	2
-ball valves, (Apollo; Model #70-104-01)	7.00	4
-packed angle shut off valve (Henry; Model 7830)	34.00	2
-sight glasses	5.00	2
-insulated heating tape, 1" x 8', 836 Watt, 120 V (Thermolyne; Cat. B00101-080)	55.00	2
-thermostat (Electric Scientific; Model SA-501A)	20.00	2
-fiber glass pipe insulation (6"ID x 1" x 3")	10.00	2
Fluid injection syringes		
-hydraulic cylinder, 2"ID by 12" stroke (Clippard; Model UDR-32x12 and hdwre)	\$ 70.00	2
-hydraulic cylinder, 3/4"ID by 10" stroke (Clippard; Model UDR12x10 and hdwre)	25.00	2
Nitrogen regulator		
-pressure regulator (Air Products; Model E11HN145G580)	\$ 173.00	1
Pressure gauges		
-30"Hg to 300 psig compound gauge (Marsh; Model J4324)	\$ 12.50	4
-0 to 500 psig refrig. pressure gauge (J/B; Model M2-500)	15.50	1

Table A.2 (Continued)

Item (Manufacturer & Model No., if appl.)	Appr. Cost	Qty
Valves		
-union bonnet, brass, 1/8" & 1/4" sizes (Whitey; Models B-ORS2 and B-1RS4)	\$ 18.00	15
-pressure relief, adjustable from 150 to 350 psig (Nupro; Model SS-4CPA2-150)	26.00	3
Miscellaneous Fittings		
-unions, tees, various adapters and tubes in sizes of 1/8", 1/4", & 1/2" dia.; brass & stainless (Swagelok)	\$ 500.00	tot
-refrigeration charging hose (Ritchie; Model HA-72)	11.00	2
Frame and panel		
-steel frame, 80 ft (Unistrut; Model P1000	\$ 100.00	tot
-assembly hardware (Unistrut; P1000 series)	100.00	tot
-plywood sheet (4' x 8' x 3/4")	25.00	1

APPENDIX B. UNCERTAINTY ANALYSIS

The experimental uncertainties applicable to the data presented in this report are determined in several ways. The uncertainties of the measured values of pressure, temperature, and viscosity are determined from a consideration of the uncertainties of the output voltage measurements and the calibration equations for each device. The propagation of error method originally presented by Kline and McClintock (1953) and discussed by Holman (1984) is used to estimate the uncertainties of the liquid density and composition. Details of these determinations are provided in the following sections.

Uncertainties of the Pressure, Temperature, and Viscosity Data

The pressure, temperature, and viscosity sensors all produce output voltages which are channelled to a Hewlett-Packard 3457A multimeter capable of d.c. voltage measurements to within 1 microvolt. If the transducers were all perfectly accurate, this voltage measurement uncertainty would translate to extremely low uncertainties of the pressure, temperature, and viscosity. However, non-linearities inherent in the transducers cause some uncertainty of these measurements.

Uncertainty of the pressure data

The calibration equation for the bonded strain gage pressure transducer is

$$P = 20.067 \cdot V + 0.1685 \quad (\text{B.1})$$

where P is the pressure in psia and V is the output voltage in mV. Thus, an output voltage uncertainty of 1 microvolt (0.001 mV) would result in an uncertainty of the pressure of about 0.02 psia. This value, however, is much less than the uncertainty of the pressure due to the non-linearity (or inaccuracy) of the transducer itself as specified by the manufacturer. For this transducer, the manufacturer's specification on non-linearity is 0.15% of full scale output, or 0.0375 mV. This translates to an uncertainty of the pressure of 0.75 psia, which is far greater than the uncertainty arising from the voltage measurement system. Therefore, for this transducer, the uncertainty of the pressure is taken to be 0.75 psia.

By a similar argument, the uncertainty of the pressure data from the capacitance sensing pressure transducer is 0.55 psia. The reported pressure at each test condition is the average of the two pressure readings, with a resulting (root mean square) uncertainty of 0.47 psia.

Uncertainty of the temperature data

Temperature data are collected from platinum resistance thermometer devices (RTDs) matched with linearizing signal conditioners. Each signal conditioner produces a current output signal of 4 to 20 mA corresponding to the desired temperature span. This signal is read as a voltage drop of 1 to 5 volts across a load resistor. For these signal conditioners, the calibrated accuracy is 0.05% of the temperature span,

which was specified to be 200°C, or 360°F (from -60°F to 300°F), when ordered from the manufacturer. Since previous discussion has shown that the uncertainty of the voltage measurement system is negligible, the uncertainty is taken as the 0.1°C (0.2°F) due to the signal conditioner accuracy.

Uncertainty of the viscosity data

The uncertainty of the viscosity data is specified by the manufacturer to be 2% of the individual reading. For the most frequently used sensor, which outputs a voltage of 0.1 to 2 volts corresponding to the viscosity range of 1 to 20 centipoise, the resulting uncertainties of the individual readings vary from 0.02 to 0.4 cp. The reported viscosity at each test condition is the mean of 20 successive viscosity readings for which the minimum acceptable scatter, defined as the standard deviation divided by the mean, is 1%. Again, the voltage measurement system uncertainty of 1 microvolt is negligible.

Uncertainty of the Liquid Density

As stated earlier, the uncertainty of the liquid density and composition is estimated using the propagation of error method proposed by Kline and McClintock for results derived from single-sample data. For a function $f = f(x, y, z, \dots)$, the uncertainty of f can be estimated by the following general propagation equation:

$$W_f = \sqrt{\left(\frac{\partial f}{\partial x} W_x\right)^2 + \left(\frac{\partial f}{\partial y} W_y\right)^2 + \left(\frac{\partial f}{\partial z} W_z\right)^2 + \dots} \quad (\text{B.2})$$

where W_x , W_y , and W_z are the uncertainties in the variables x , y , and z , all given with the same probability. In the special case where the function is a product or

ratio of these terms, for example, $f = x \cdot y/z$, then the relative uncertainty may be expressed in a more convenient form:

$$\frac{W_f}{f} = \sqrt{\left(\frac{W_x}{x}\right)^2 + \left(\frac{W_y}{y}\right)^2 + \left(\frac{W_z}{z}\right)^2} \quad (\text{B.3})$$

Both of the above forms of the propagation equation are employed in the following analysis.

The basic equation for the density of the liquid is

$$\rho_L = \frac{m_L}{V_L} \quad (\text{B.4})$$

where m_L is the mass of the liquid in the cell and V_L is the volume that the liquid occupies. The relative uncertainty of ρ_L is

$$\frac{W_{\rho_L}}{\rho_L} = \sqrt{\left(\frac{W_{m_L}}{m_L}\right)^2 + \left(\frac{W_{V_L}}{V_L}\right)^2} \quad (\text{B.5})$$

where W_{m_L} and W_{V_L} are the uncertainties of the mass of the liquid in the cell and of the liquid volume, respectively. These uncertainties are calculated in the following sections. Determination of W_{V_L} is more straightforward and is discussed first. Following this, a propagation of error method is used to calculate W_{m_L} for an example case.

Uncertainty of the liquid volume

The calibration equation for the liquid volume as a function of the liquid - vapor interface level, h , is

$$V_L = 274.66 \cdot h - 4393.6 \quad (\text{B.6})$$

where V_L is in milliliters (mL) and h is the liquid level reading in inches, measured using a steel scale attached to the window of the cell. An arbitrary reference value

of 20" has been assigned to the very bottom of the 12-inch long window slot, and, therefore, the scale reads 32" at the top of the window. This scale is ruled in sixteenths of an inch. Thus, the uncertainty in the level reading, W_h , is approximately 0.031 inch, with a corresponding uncertainty of the liquid volume of $W_{V_L} = 274.26 \cdot W_h = 8.6 \text{ mL}$.

Uncertainty of the liquid mass

The determination of the uncertainty of the mass of liquid in the cell is complicated by the successive additions and sample withdrawals that are made as the refrigerant concentrations are changed during the course of a typical test run. Thus, the total mass of liquid in the test cell at any particular test condition is

$$m_L = m_{O,inj} + m_{R,inj} - m_S - m_{R,V} \quad (\text{B.7})$$

where $m_{O,inj}$ is the mass of oil injected at the start of testing, $m_{R,inj}$ is the sum of the masses of initial and subsequent injections of refrigerant into the cell, m_S is the total mass of liquid removed from the cell due to sampling since the initial injections of oil and/or refrigerant, and $m_{R,V}$ is the mass of the vapor (which is assumed to be pure refrigerant). The uncertainty of the mass of the liquid is then:

$$W_{m_L} = \sqrt{\left(W_{m_{O,inj}}\right)^2 + \left(W_{m_{R,inj}}\right)^2 + \left(W_{m_S}\right)^2 + \left(W_{m_{R,V}}\right)^2} \quad (\text{B.8})$$

The four terms contributing to W_{m_L} are examined in turn for the following example test situation.

History:

- Test run beginning with pure alkylbenzene
- Refrigerant-22 added in 4 separate injections to allow testing at liquid compositions of 10%, 20%, 30%, and 40% refrigerant mass fraction
- One sample withdrawn at the end of testing of each composition including pure oil

Current conditions:

- Liquid composition: $x_R = 41.4\%$ (refrigerant mass fraction)
- Liquid level: $h = 29.78''$ at 57.4°C
- Liquid and vapor volumes: $V_L = 3774 \text{ mL}$; $V_V = 1413 \text{ mL}$
- Vapor conditions: $P = 1.846 \text{ MPa}$ at 59.3°C
- Total oil injected: $m_{O,inj} = 2375 \text{ g}$
- Total refrigerant injected: $m_{R,inj} = 1650 \text{ g}$
- Room temperature density of oil: $\rho_O = 0.87 \text{ g/mL}$
- Room temperature density of liquid R-22: $\rho_{R,L} = 1.210 \text{ g/mL}$
- Total liquid removed in prior samplings: $m_S = 292 \text{ g}$
Oil and refrigerant portions: $m_{O,S} = 247 \text{ g}$; $m_{R,S} = 45 \text{ g}$
- Contents remaining: $m_O = 2128 \text{ g}$; $m_R = 1605 \text{ g}$
- Refrigerant distribution: $m_{R,L} = 1500 \text{ g}$; $m_{R,V} = 105 \text{ g}$

Uncertainty of the mass of oil injected: The mass of oil injected is

$$m_{O,inj} = V_O \cdot \rho_O \quad (\text{B.9})$$

where V_O is the volume of oil injected at room temperature and ρ_O is the density of the pure oil at room temperature. The relative uncertainty of the mass of oil injected is

$$\frac{W_{m_{O,inj}}}{m_{O,inj}} = \sqrt{\left(\frac{W_{V_O}}{V_O}\right)^2 + \left(\frac{W_{\rho_O}}{\rho_O}\right)^2} \quad (\text{B.10})$$

Now $V_O = H \cdot F$, where H is the total stroke, in inches, of the injection cylinder to give the full amount of oil injected, and F is the calibrated volume displacement per inch of stroke. $F = 51.15$ mL/inch for the cylinder used for the oil injection. The uncertainty of the volume of oil injected is $W_{V_O} = F \cdot W_H$, where W_H is the uncertainty of H . For this example, 2375 g (2730 mL) of oil are injected, requiring five separate fill-and-discharge cycles of the injection cylinder. The associated total uncertainty is

$$W_H = \sqrt{5 \left[(W_{h_s})^2 + (W_{h_e})^2 \right]} \quad (\text{B.11})$$

where W_{h_s} and W_{h_e} are the uncertainties of the positions of the injection cylinder piston at the start and at the end, respectively, of each of the five injection cycles. Since the scales used with the injection cylinders are calibrated in sixteenths of an inch, both W_{h_s} and W_{h_e} are about 0.031 inch. Therefore, W_H is approximately 0.1 inch, and the resulting uncertainty of the volume of oil injected, W_{V_O} , is 5.1 mL.

Further, it is estimated that ρ_O at room temperature is known to within $W_{\rho_O} = 0.005$ g/mL. Equation B.10 can now be solved to give $\underline{W_{m_{O,inj}}} = 14.4$ g.

Uncertainty of the mass of refrigerant injected: The mass of refrigerant injected and the uncertainty of that mass arising from successive injections of refrigerant is calculated in a manner similar to that for the oil injection.

$$m_{R,inj} = V_{R,inj} \cdot \rho_{R,L} \quad (\text{B.12})$$

$$\frac{W_{m_{R,inj}}}{m_{R,inj}} = \sqrt{\left(\frac{W_{V_{R,inj}}}{V_{R,inj}} \right)^2 + \left(\frac{W_{\rho_{R,L}}}{\rho_{R,L}} \right)^2} \quad (\text{B.13})$$

For the example case, 5 fill-and-discharge cycles of the refrigerant injection cylinder are required to successively test the five different compositions from pure oil to 40%

refrigerant. This fact results in a similar injection volume uncertainty as that for the oil. Thus, $W_{V_{R,inj}} = 5.1$ mL.

The uncertainty of the density of the refrigerant liquid (injected as slightly compressed liquid at room temperature) is conservatively estimated as $W_{\rho_{R,L}} = 0.002$ g/mL. For the example case, $\rho_{R,L} = 1.210$ g/mL and $V_{R,inj} = 1364$ mL. The uncertainty of the total mass of refrigerant charged is calculated by substituting the above into Eq. B.13: $W_{m_{R,inj}} = 6.8$ g.

Uncertainty of the mass withdrawn in sampling: Most of the mass of liquid withdrawn from the test cell in an individual sampling is contained in the sampling chamber, but a small amount is also trapped in the short lengths of tubing between the pairs of isolation valves on either side of the sample chamber. When the sampling chamber is removed, this small amount of trapped liquid is decompressed, refrigerant vapor evolves from it, and the rest of the liquid is drained and “lost”. The mass of liquid in the sample chamber is simply determined by subtracting the mass of the clean, evacuated sample chamber from the mass of the full chamber prior to venting the contents. Thus, the total amount of liquid removed from the test cell for each sampling operation is

$$m_{s,i} = m_{smp,i} + m_{lost,i} = m_{full,i} - m_{evac,i} + m_{lost,i} \quad (B.14)$$

The uncertainty of the mass of liquid removed during each sampling is then

$$W_{m_{s,i}} = \sqrt{\left(W_{m_{full,i}}\right)^2 + \left(W_{m_{evac,i}}\right)^2 + \left(W_{m_{lost,i}}\right)^2} \quad (B.15)$$

For the example case, a total of four samples have been withdrawn prior to the current test situation. The uncertainty of the total mass withdrawn from the test

cell is therefore

$$W_{m_S} = \sqrt{4 \left[\left(W_{m_{full,i}} \right)^2 + \left(W_{m_{evac,i}} \right)^2 + \left(W_{m_{lost,i}} \right)^2 \right]} \quad (\text{B.16})$$

The electronic balance used in the tests is capable of determining mass to within 0.01 g, so that $W_{m_{full,i}} = W_{m_{evac,i}} = 0.01$ g at most.

The mass of the “lost” fluid must be determined from the calculated density of the sample and the volume of liquid in the tubing between the two isolation valves on each side of the sampling chamber:

$$m_{lost,i} = V_{lost} \cdot \rho_{samp,i} \quad (\text{B.17})$$

Thus,

$$\frac{W_{m_{lost,i}}}{m_{lost,i}} = \sqrt{\left(\frac{W_{V_{lost}}}{V_{lost}} \right)^2 + \left(\frac{W_{\rho_{samp,i}}}{\rho_{samp,i}} \right)^2} \quad (\text{B.18})$$

Now V_{lost} is approximately 5 mL and $W_{V_{lost}}$ is estimated to be 0.5 mL. The density of the sample is calculated from the mass and volume of the particular sample:

$$\rho_{samp,i} = \frac{m_{samp,i}}{V_{samp,i}} \quad (\text{B.19})$$

The relative uncertainty of this liquid density is

$$\frac{W_{\rho_{samp,i}}}{\rho_{samp,i}} = \sqrt{\left(\frac{W_{m_{samp,i}}}{m_{samp,i}} \right)^2 + \left(\frac{W_{V_{samp,i}}}{V_{samp,i}} \right)^2} \quad (\text{B.20})$$

It can be inferred from Equations B.14 and B.15 that

$$W_{m_{samp,i}} = \sqrt{\left(W_{m_{full,i}} \right)^2 + \left(W_{m_{evac,i}} \right)^2} \quad (\text{B.21})$$

so the uncertainty of the sample mass would be no more than 0.014 g. $W_{V_{samp,i}}$ is estimated to be 0.2 mL. If, for example, $V_{samp,i}$ is 75 mL, and $m_{samp,i}$ is approximately 70 g, then $\rho_{samp,i}$ is 0.93 g/mL. Thus, $W_{\rho_{samp,i}} = 0.0025$ g/mL. With

these results, the liquid “lost” in the fittings is approximately 4.7 g and Eq. B.18 yields $W_{m_{lost,i}}$ approximately equal to 0.5 g, conservatively estimated. An estimate of the uncertainty of the total mass withdrawn from the test cell after four sampling operations can now be estimated using Eq. B.16: $W_{m_S} = 1.0$ g.

Uncertainty of the mass of the vapor: In the tests reported on in this work, the vapor above the oil-refrigerant solution is assumed to be pure refrigerant. The mass of the vapor can then be calculated from the volume of the vapor space, V_V , and the density of the pure refrigerant vapor, $\rho_{R,V}$, at the temperature and pressure of the vapor:

$$m_{R,V} = V_V \cdot \rho_{R,V} \quad (\text{B.22})$$

The relative uncertainty of $m_{R,V}$ is

$$\frac{W_{m_{R,V}}}{m_{R,V}} = \sqrt{\left(\frac{W_{V_V}}{V_V}\right)^2 + \left(\frac{W_{\rho_{R,V}}}{\rho_{R,V}}\right)^2} \quad (\text{B.23})$$

Now W_{V_V} , the uncertainty of the vapor volume, is related to the uncertainty of the height of the liquid-vapor interface that was discussed previously in the subsection on liquid volume, i.e., $W_{V_V} = W_{V_L} = 8.6$ mL.

The refrigerant vapor density is a function of temperature and pressure, and is calculated using a computerized property routine. An estimate of the uncertainty of the vapor density requires the partial derivatives of the vapor density with respect to both pressure and temperature, as follows:

$$W_{\rho_{R,V}} = \sqrt{\left(\frac{\partial \rho_{R,V}}{\partial P} W_P\right)^2 + \left(\frac{\partial \rho_{R,V}}{\partial T} W_T\right)^2} \quad (\text{B.24})$$

The partial derivatives were estimated numerically at the temperature and pressure of the vapor in the example case. They are

$$\frac{\partial \rho_{R,V}}{\partial P} = 0.055 \frac{(g/mL)}{MPa}$$

and

$$\frac{\partial \rho_{R,V}}{\partial T} = -0.0005 \frac{(g/mL)}{^{\circ}C}.$$

As discussed earlier, the estimates of the uncertainty for pressure and temperature are $W_P = 0.75 \text{ psia} = 0.00517 \text{ MPa}$ and $W_T = 0.1 \text{ }^{\circ}C$. Thus, $W_{\rho_{R,V}}$ is 0.00029 g/mL. The vapor density, $\rho_{R,V}$, is 0.07410 g/mL at these conditions. The mass of the vapor is then 104.7 g. Now Eq. B.23 is employed to find $W_{m_{R,V}} = 0.75 \text{ g}$.

Summary of the uncertainty of the liquid density

The uncertainties estimated in the preceding four sections are returned to Eq. B.8 to determine that $W_{m_L} = 16.0 \text{ g}$. The component uncertainties are listed below for comparison.

- $W_{m_{O,inj}} = 14.4 \text{ g}$
- $W_{m_{R,inj}} = 6.8 \text{ g}$
- $W_{m_S} = 1.0 \text{ g}$
- $W_{m_{R,V}} = 0.75 \text{ g}$

It is clear that the major contributions to the uncertainty of the mass of the liquid are the uncertainties of the masses of oil and refrigerant injected. A review of the calculations shows that the predominant causes are the uncertainties of the densities of the oil and the refrigerant as injected.

With the results from all of the foregoing discussion, it is now finally possible to solve for the uncertainty of the liquid density, W_{ρ_L} , the goal of this major section. For the example case, with $m_L = 3628$ g and $V_L = 3774$ mL, Eq. B.5 gives a relative uncertainty of the liquid density of about 0.0050, or one-half of one percent. Now $\rho_L = 0.961$ g/mL in this case, so $W_{\rho_L} = 0.0048$ g/mL.

It should be noted that this uncertainty will vary somewhat for each test condition, since its magnitude depends on both the test condition itself and also on the history of the test run prior to the condition of interest. To understand the significance of the magnitude of W_{ρ_L} , it is useful to compare this estimate to the total variation in the liquid density across the entire range of test conditions. The liquid density range is from 0.782 g/mL (for pure oil at 148.4°C) to 0.985 g/mL (for this nominal 40% refrigerant mixture at 38.5°C), for an overall variation of 0.203 g/mL. Thus, W_{ρ_L} is only about 2% of the overall variation in the liquid density, and the "signal-to-noise" ratio is reasonably high.

Uncertainty of the Liquid Composition

In this work, the composition of the liquid is given in terms of refrigerant mass fraction. Though it is checked by sampling once at each nominal composition, the refrigerant mass fraction is calculated as follows for each data point:

$$x_R = \frac{m_{R,L}}{m_L} \quad (\text{B.25})$$

where the mass of refrigerant dissolved in the liquid is

$$m_{R,L} = m_{R,inj} - m_{R,V} - m_{R,S} \quad (\text{B.26})$$

Previous sections of this appendix have outlined the calculation of all of the above terms and their uncertainties, except for $m_{R,S}$, which is the refrigerant portion of m_S , the total mass withdrawn from the test cell due to prior sampling operations. Accordingly,

$$m_{R,S} = \sum (m_{R,s})_i = \sum (m_{s,i} \cdot x_{R,i}) \quad (\text{B.27})$$

with the subscript 'i' referring to prior individual samples.

Now the relative uncertainty of the liquid composition is

$$\frac{W_{xR}}{x_R} = \sqrt{\left(\frac{W_{m_{R,L}}}{m_{R,L}}\right)^2 + \left(\frac{W_{m_L}}{m_L}\right)^2} \quad (\text{B.28})$$

and the uncertainty of $m_{R,L}$ is

$$W_{m_{R,L}} = \sqrt{\left(W_{m_{R,inj}}\right)^2 + \left(W_{m_{R,V}}\right)^2 + \left(W_{m_{R,S}}\right)^2} \quad (\text{B.29})$$

The above two equations contain only one uncertainty term which has not been estimated in previous sections, i.e., $W_{m_{R,S}}$. Referring to Eq. B.27, this uncertainty can be calculated as:

$$W_{m_{R,S}} = \sqrt{\sum \left(W_{m_{R,s}}\right)_i^2} \quad (\text{B.30})$$

Now for each prior sampling except for the first which contained no refrigerant,

$$\left(\frac{W_{m_{R,s}}}{m_{R,s}}\right)_i = \sqrt{\left(\frac{W_{m_{s,i}}}{m_{s,i}}\right)^2 + \left(\frac{W_{x_{R,i}}}{x_{R,i}}\right)^2} \quad (\text{B.31})$$

The term $W_{m_{s,i}}$ has been discussed in a previous section (see Eq. B.15) and is approximately 0.5 g. Now $W_{x_{R,i}}$ remains to be calculated for each of the prior samplings. Noting that

$$x_{R,i} = m_{(R,samp),i} / m_{samp,i} \quad (\text{B.32})$$

where $m_{(R,samp),i}$ is the mass of refrigerant in the sample, the relative uncertainty of $x_{R,i}$ is then

$$\left(\frac{W_{x_{R,i}}}{x_{R,i}} \right) = \sqrt{\left(\frac{W_{m_{R,samp}}}{m_{R,samp}} \right)_i^2 + \left(\frac{W_{m_{samp}}}{m_{samp}} \right)_i^2} \quad (\text{B.33})$$

Both $W_{m_{(R,samp),i}}$ and $W_{m_{samp,i}}$ involve uncertainties of the differences of masses. From previous discussion, $W_{m_{samp,i}} = 0.014$ g. Since $m_{(R,samp),i}$ is determined in a similar manner, $W_{(R,samp),i} = 0.014$ g also.

Using Equations B.31 and B.33, the contributing terms of Equation B.30 can be estimated for each prior sample (except the first, which contained no refrigerant) as summarized below:

- For sample 2: $x_{R,2} = 0.10$, $m_{samp,2} = 67$ g, $m_{(R,samp),2} = 6.7$ g, and $W_{x_{R,2}} = 0.00021$. Now $m_{s,2} = 71$ g, $m_{(R,s),2} = 7.1$ g, and thus, $W_{m_{(R,s),2}} = 0.052$ g.
- For sample 3: $x_{R,3} = 0.20$, $m_{samp,3} = 70$ g, $m_{(R,samp),3} = 14$ g, and $W_{x_{R,3}} = 0.00020$. Now $m_{s,3} = 74.2$ g, $m_{(R,s),3} = 14.8$ g, and thus, $W_{m_{(R,s),3}} = 0.101$ g.
- For sample 4: $x_{R,4} = 0.30$, $m_{samp,4} = 72$ g, $m_{(R,samp),4} = 21.6$ g, and $W_{x_{R,4}} = 0.00020$. Now $m_{s,4} = 76.3$ g, $m_{(R,s),4} = 22.9$ g, and thus, $W_{m_{(R,s),4}} = 0.151$ g.

Equations B.30, B.29, and B.28 are then used in turn to give $W_{m_{R,S}} = 0.189$ g, $W_{m_{R,L}} = 6.84$ g, and $W_{x_R} = 0.0026$, respectively, for this example test case.

As is the case for the uncertainty of the liquid density, the influence of the history of prior sampling and injection operations is evident. Similar calculations for

the other liquid compositions tested prior to the current condition in this example would show that the uncertainties in the compositions are smaller.

APPENDIX C. LISTING OF EXPERIMENTAL DATA

Experimental results of the oil/refrigerant property studies are provided in the following tables. These data have been reduced from the actual "raw" test run data as outlined in Chapter 3 and in Appendix B. They form the bases upon which the empirical correlations discussed in Chapters 4 and 5 are derived.

As noted in chapter 4, the temperature at which the solubilities (pressures) are recorded is an estimated liquid-vapor interface temperature that is an average of the vapor temperature and the average liquid temperature. This was done because of some non-uniformity in temperatures throughout the test cell, even at steady conditions. Viscosities are reported at the operating temperature of the viscometer and the average liquid temperature is used to report the liquid densities.

Tables C.1, C.2, and C.3 list the solubility, viscosity, and density data, respectively, for solutions of R-22 in a 150 SUS napthenic oil. These are the earliest data taken in the project. The numbers of solubility, viscosity, and density data points are different, because of early variations in data collection procedures. These procedures were later made more concise. Thus, for the other oil/refrigerant pairs, the solubility (pressure) and the viscosity and density of the liquid were evaluated at the same test conditions, and for each of these solutions the numbers of solubility, viscosity, and density data points are the same. Tables C.4, C.5, and C.6 list the data for solutions

of R-22 and a 150 SUS alkylbenzene. Similarly, Tables C.7 through C.12 provide this information for solutions of R-502 in these same lubricants.

Table C.1: Experimental solubility (vapor pressure) data for R-22/150 SUS naphthenic oil solutions

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-22)
57.5	0.000	0.000
104.0	0.000	0.000
104.3	0.000	0.000
117.8	0.000	0.000
134.1	0.000	0.000
135.8	0.000	0.000
143.9	0.000	0.000
144.4	0.000	0.000
115.0	0.000	0.000
108.7	0.000	0.000
73.2	0.000	0.000
51.7	0.000	0.000
40.7	0.685	0.093
60.2	0.780	0.092
84.4	1.031	0.087
84.5	1.033	0.087
107.7	1.297	0.082
135.8	1.613	0.078
62.8	0.849	0.090
62.1	0.825	0.091
62.0	0.821	0.091
38.9	0.638	0.114
47.2	0.734	0.113
47.9	0.743	0.112
68.8	1.007	0.109
86.2	1.234	0.107
102.3	1.455	0.105
101.5	1.469	0.104
112.1	1.625	0.103
131.4	1.943	0.101
140.2	2.073	0.100

Table C.1 (Continued)

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-22)
62.5	1.452	0.181
76.9	1.766	0.175
95.3	2.184	0.168
95.3	2.184	0.168
49.2	1.177	0.187
85.4	1.949	0.172
46.1	1.115	0.189
85.8	1.964	0.172
114.3	2.630	0.161
128.2	2.956	0.156
97.8	2.254	0.166
96.0	2.201	0.167
48.5	1.152	0.188
44.8	1.096	0.189
39.7	1.039	0.202
58.0	1.431	0.198
59.0	1.469	0.198
76.6	1.899	0.195
79.0	1.998	0.194
87.1	2.211	0.192
89.4	2.289	0.192
96.6	2.494	0.191
104.5	2.712	0.189
113.9	3.009	0.188
123.6	3.314	0.186
37.0	1.170	0.336
38.6	1.256	0.335
47.6	1.456	0.334
48.2	1.519	0.333
50.3	1.541	0.333
55.6	1.728	0.333
55.6	1.732	0.332
56.5	1.731	0.331
56.4	1.732	0.331
56.5	1.738	0.331
56.8	1.778	0.331
60.5	1.846	0.330
61.0	1.859	0.330

Table C.1 (Continued)

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-22)
64.9	2.046	0.330
65.0	2.049	0.330
65.1	2.049	0.330
72.9	2.179	0.328
70.6	2.192	0.328
73.1	2.349	0.328
75.1	2.439	0.325
93.3	3.211	0.321
44.1	1.476	0.387
48.9	1.637	0.383
58.0	1.942	0.376
58.7	1.969	0.375
67.1	2.283	0.368
67.7	2.330	0.366
76.6	2.672	0.358
88.0	3.143	0.346
88.1	3.150	0.346

Table C.2: Experimental viscosity data for R-22/150 SUS naphthenic oil solutions

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-22)
59.9	10.99	0.000
104.0	3.37	0.000
104.3	3.34	0.000
117.8	2.57	0.000
134.1	1.92	0.000
135.8	1.87	0.000
143.9	1.64	0.000
144.4	1.62	0.000
115.0	2.57	0.000
108.7	3.02	0.000
74.6	7.08	0.000
54.4	13.48	0.000
44.0	10.48	0.093
58.8	6.18	0.092
81.7	3.37	0.087
81.8	3.38	0.087
103.5	2.07	0.082
129.4	1.19	0.078
62.9	5.73	0.090
62.1	5.84	0.091
62.1	5.85	0.091
98.8	1.86	0.104
107.0	1.60	0.103
126.0	1.22	0.101
133.8	1.10	0.100
63.3	2.90	0.181
76.9	2.16	0.175
94.0	1.54	0.168
94.0	1.55	0.168
50.8	3.99	0.187
84.6	1.86	0.172
47.9	4.39	0.189
84.6	1.93	0.172
112.4	0.97	0.161

Table C.2 (Continued)

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-22)
125.7	0.76	0.156
96.9	1.56	0.166
95.2	1.65	0.167
49.8	4.10	0.188
47.0	4.52	0.189
75.3	2.24	0.195
78.3	1.96	0.194
86.3	1.74	0.192
88.7	1.64	0.192
95.3	1.48	0.191
102.1	1.32	0.189
110.9	1.18	0.188
120.2	1.05	0.186
39.5	2.18	0.335
46.7	1.91	0.334
48.0	1.83	0.333
49.0	1.84	0.333
54.7	1.65	0.331
55.3	1.72	0.331
55.3	1.61	0.331
57.4	1.57	0.330
58.3	1.55	0.330
66.0	1.37	0.328
45.4	1.69	0.387
50.0	1.47	0.383
58.1	1.31	0.376
59.5	1.35	0.375
66.5	1.22	0.368
68.3	1.18	0.366
75.9	1.03	0.358
86.2	0.95	0.346
86.4	0.96	0.346

Table C.3: Experimental density data for R-22/150 SUS naphthenic oil solutions

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-22)
57.5	0.876	0.000
104.0	0.849	0.000
104.3	0.849	0.000
117.8	0.841	0.000
134.1	0.832	0.000
135.8	0.831	0.000
143.9	0.826	0.000
144.4	0.826	0.000
115.0	0.843	0.000
108.7	0.846	0.000
73.2	0.866	0.000
51.7	0.878	0.000
41.0	0.945	0.093
58.6	0.931	0.092
81.7	0.914	0.087
81.8	0.914	0.087
104.2	0.898	0.082
131.2	0.879	0.078
61.0	0.929	0.090
60.5	0.930	0.091
60.4	0.930	0.091
112.9	0.915	0.181
112.9	0.915	0.181
101.9	0.924	0.183
101.9	0.924	0.183
91.3	0.933	0.185
91.3	0.933	0.185
91.3	0.933	0.185
81.1	0.942	0.188
81.0	0.942	0.188
67.6	0.952	0.191
67.4	0.952	0.191
54.3	0.964	0.194
42.6	0.973	0.197

Table C.3 (Continued)

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-22)
83.7	0.962	0.288
75.2	0.970	0.290
75.2	0.970	0.290
66.4	0.978	0.292
66.4	0.978	0.292
57.4	0.987	0.294
57.4	0.987	0.294
45.8	0.997	0.297
45.5	0.998	0.297

Table C.4: Experimental solubility (vapor pressure) data for R-22/150 SUS alkyl-benzene solutions

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-22)
43.7	0.000	0.000
44.0	0.000	0.000
44.0	0.000	0.000
70.9	0.000	0.000
72.6	0.000	0.000
98.9	0.000	0.000
99.5	0.000	0.000
81.2	0.000	0.000
81.2	0.000	0.000
117.6	0.000	0.000
117.6	0.000	0.000
135.3	0.000	0.000
135.3	0.000	0.000
148.4	0.000	0.000
148.4	0.000	0.000
148.4	0.000	0.000
66.7	0.628	0.089
67.0	0.632	0.089
86.0	0.806	0.087
104.3	1.041	0.085
117.3	1.173	0.084
128.0	1.277	0.083
132.8	1.334	0.083
136.2	1.406	0.082
136.5	1.419	0.082
150.1	1.583	0.081
150.2	1.590	0.081
144.6	1.538	0.082
143.7	1.529	0.082
137.2	1.441	0.082
137.1	1.438	0.082
118.2	1.207	0.083
110.7	1.147	0.084
105.7	1.081	0.084

Table C.4 (Continued)

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-22)
104.7	1.059	0.085
95.5	0.975	0.085
91.2	0.905	0.086
78.6	0.778	0.087
77.5	0.757	0.087
63.7	0.626	0.089
62.8	0.620	0.089
61.8	0.602	0.089
53.3	1.048	0.199
53.5	1.055	0.199
66.3	1.310	0.197
90.0	1.890	0.193
90.1	1.892	0.193
104.0	2.277	0.191
104.0	2.277	0.191
117.9	2.682	0.190
118.0	2.681	0.190
129.2	2.994	0.189
136.9	3.236	0.188
136.3	3.227	0.188
136.3	3.225	0.188
127.1	2.965	0.189
122.7	2.812	0.189
122.5	2.805	0.189
108.5	2.417	0.191
105.2	2.304	0.191
104.4	2.280	0.191
90.2	1.892	0.193
90.1	1.892	0.193
81.7	1.751	0.194
81.3	1.670	0.195
80.6	1.656	0.195

Table C.4 (Continued)

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-22)
70.9	1.455	0.196
67.5	1.349	0.197
67.4	1.347	0.197
35.3	0.964	0.327
43.8	1.145	0.324
53.0	1.418	0.320
75.3	2.098	0.310
83.5	2.372	0.306
94.8	2.839	0.299
103.8	3.184	0.295
90.2	2.657	0.302
90.2	2.658	0.302
83.9	2.429	0.305
75.5	2.134	0.309
75.5	2.133	0.309
63.6	1.747	0.315
63.6	1.746	0.315
53.3	1.446	0.319
53.3	1.446	0.319
35.7	1.147	0.419
40.6	1.276	0.418
41.6	1.311	0.418
62.8	2.009	0.412
71.7	2.367	0.409
87.8	3.126	0.403
81.9	2.817	0.406
79.2	2.711	0.407
74.4	2.485	0.409
60.2	1.898	0.413
59.8	1.886	0.413
58.3	1.846	0.414

Table C.5: Experimental viscosity data for R-22/150 SUS alkylbenzene solutions

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-22)
47.0	17.21	0.000
47.2	16.68	0.000
46.6	17.26	0.000
72.5	6.91	0.000
74.0	6.56	0.000
98.9	3.52	0.000
99.5	3.46	0.000
82.1	5.21	0.000
82.1	5.22	0.000
117.6	2.39	0.000
117.6	2.40	0.000
135.3	1.79	0.000
135.3	1.78	0.000
148.4	1.46	0.000
148.4	1.47	0.000
148.4	1.46	0.000
67.2	4.43	0.089
67.5	4.43	0.089
85.1	2.92	0.087
102.3	2.08	0.085
114.9	1.67	0.084
124.4	1.44	0.083
129.9	1.32	0.083
133.3	1.25	0.082
133.5	1.25	0.082
146.7	1.04	0.081
146.9	1.04	0.081
141.8	1.09	0.082
140.7	1.12	0.082
134.1	1.24	0.082
134.0	1.25	0.082
115.7	1.67	0.083
108.3	1.86	0.084
103.4	2.05	0.084

Table C.5 (Continued)

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-22)
102.6	2.08	0.085
93.5	2.47	0.085
89.9	2.70	0.086
78.4	3.34	0.087
77.6	3.42	0.087
65.3	4.75	0.089
63.9	4.91	0.089
62.5	4.98	0.089
55.4	2.86	0.199
55.6	2.90	0.199
67.2	2.28	0.197
88.6	1.58	0.193
88.6	1.56	0.193
101.7	1.19	0.191
101.7	1.20	0.191
115.3	0.96	0.190
115.5	0.95	0.190
126.1	0.82	0.189
134.1	0.75	0.188
133.4	0.75	0.188
133.4	0.75	0.188
124.3	0.85	0.189
120.1	0.90	0.189
119.9	0.91	0.189
105.9	1.13	0.191
102.9	1.18	0.191
102.2	1.19	0.191
88.8	1.51	0.193
88.7	1.51	0.193
80.9	1.68	0.194
80.6	1.75	0.195
79.8	1.78	0.195
70.8	2.13	0.196

Table C.5 (Continued)

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-22)
67.9	2.25	0.197
67.8	2.25	0.197
37.6	2.17	0.327
45.0	1.78	0.324
54.4	1.45	0.320
74.5	1.08	0.310
81.6	0.99	0.306
92.5	0.83	0.299
100.8	0.80	0.295
88.2	0.89	0.302
88.2	0.89	0.302
82.6	1.03	0.305
75.0	1.09	0.309
75.0	1.10	0.309
64.3	1.26	0.315
64.3	1.27	0.315
55.0	1.53	0.319
55.0	1.53	0.319
39.6	1.13	0.419
43.9	1.04	0.418
44.7	1.02	0.418
63.8	0.79	0.412
71.8	0.71	0.409
61.0	0.84	0.413
60.8	0.84	0.413
59.8	0.82	0.414

Table C.6: Experimental density data for R-22/150 SUS alkylbenzene solutions

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-22)
43.7	0.852	0.000
44.0	0.852	0.000
44.0	0.852	0.000
70.9	0.834	0.000
72.6	0.833	0.000
98.9	0.815	0.000
99.5	0.815	0.000
81.2	0.827	0.000
81.2	0.827	0.000
117.6	0.803	0.000
117.6	0.803	0.000
135.3	0.791	0.000
135.3	0.791	0.000
148.4	0.782	0.000
148.4	0.782	0.000
148.4	0.782	0.000
65.3	0.866	0.089
65.6	0.864	0.089
84.4	0.854	0.087
102.3	0.841	0.085
114.9	0.832	0.084
124.4	0.825	0.083
129.9	0.821	0.083
133.3	0.819	0.082
133.5	0.819	0.082
146.7	0.811	0.081
146.9	0.811	0.081
141.8	0.814	0.082
140.7	0.814	0.082
134.1	0.820	0.082
134.0	0.820	0.082
115.7	0.832	0.083
108.3	0.837	0.084
103.4	0.840	0.084

Table C.6 (Continued)

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-22)
102.6	0.840	0.085
93.4	0.848	0.085
89.5	0.850	0.086
77.2	0.858	0.087
76.4	0.860	0.087
63.2	0.869	0.089
61.8	0.869	0.089
60.3	0.870	0.089
52.7	0.892	0.199
52.9	0.892	0.199
65.3	0.883	0.197
88.1	0.864	0.193
88.2	0.864	0.193
101.7	0.853	0.191
101.7	0.853	0.191
115.3	0.843	0.190
115.5	0.843	0.190
126.1	0.833	0.189
134.1	0.828	0.188
133.4	0.829	0.188
133.4	0.829	0.188
124.3	0.836	0.189
120.1	0.839	0.189
119.9	0.839	0.189
105.9	0.850	0.191
102.9	0.853	0.191
102.2	0.854	0.191
88.3	0.864	0.193
88.2	0.864	0.193
80.0	0.871	0.194
79.7	0.872	0.195
78.7	0.872	0.195
69.2	0.881	0.196

Table C.6 (Continued)

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-22)
66.0	0.882	0.197
66.0	0.882	0.197
33.7	0.960	0.327
41.6	0.951	0.324
51.7	0.939	0.320
73.1	0.917	0.310
80.7	0.911	0.306
92.3	0.898	0.299
100.8	0.890	0.295
87.7	0.903	0.302
87.7	0.903	0.302
81.8	0.909	0.305
73.7	0.918	0.309
73.7	0.918	0.309
62.2	0.930	0.315
62.2	0.930	0.315
52.3	0.942	0.319
52.3	0.942	0.319
35.8	0.985	0.419
40.4	0.978	0.418
41.3	0.977	0.418
61.7	0.955	0.412
70.3	0.945	0.409
58.7	0.960	0.413
58.4	0.959	0.413
57.4	0.961	0.414

Table C.7: Experimental solubility (vapor pressure) data for R-502/150 SUS naphthenic oil solutions

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-502)
57.5	0.000	0.000
104.0	0.000	0.000
104.3	0.000	0.000
117.8	0.000	0.000
134.1	0.000	0.000
135.8	0.000	0.000
143.9	0.000	0.000
144.4	0.000	0.000
115.0	0.000	0.000
108.7	0.000	0.000
73.2	0.000	0.000
51.7	0.000	0.000
150.0	2.225	0.087
139.3	2.045	0.087
128.3	1.868	0.088
117.2	1.694	0.089
106.2	1.531	0.090
95.0	1.371	0.091
84.6	1.233	0.092
74.1	1.104	0.093
61.9	0.963	0.094
55.0	0.901	0.094
44.5	0.776	0.096
42.0	0.743	0.096
113.6	3.228	0.180
104.5	2.946	0.181
95.6	2.684	0.182
86.3	2.408	0.184
77.2	2.148	0.186
68.1	1.899	0.188
59.7	1.685	0.190
49.2	1.407	0.193
45.6	1.339	0.194
40.0	1.217	0.195

Table C.7 (Continued)

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-502)
35.7	1.342	0.294
41.1	1.535	0.289
47.7	1.754	0.284
47.7	1.757	0.284
57.0	2.069	0.276
57.1	2.073	0.276
65.5	2.354	0.270
65.5	2.355	0.270
74.0	2.645	0.264
74.1	2.650	0.263
83.2	2.982	0.256
83.2	2.982	0.256
92.3	3.319	0.250
92.3	3.318	0.250

Table C.8: Experimental viscosity data for R-502/150 SUS naphthenic oil solutions

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-502)
59.9	10.99	0.000
104.0	3.37	0.000
104.3	3.34	0.000
117.8	2.57	0.000
134.1	1.92	0.000
135.8	1.87	0.000
143.9	1.64	0.000
144.4	1.62	0.000
115.0	2.57	0.000
108.7	3.02	0.000
74.6	7.08	0.000
54.4	13.48	0.000
146.1	1.09	0.087
135.6	1.26	0.087
124.9	1.48	0.088
114.2	1.75	0.089
103.6	2.08	0.090
92.8	2.55	0.091
83.5	3.12	0.092
73.9	3.95	0.093
62.9	5.50	0.094
56.5	6.35	0.094
47.3	8.57	0.096
45.2	9.25	0.096
111.3	1.31	0.180
102.3	1.50	0.181
93.8	1.76	0.182
85.3	1.93	0.184
77.1	2.26	0.186
68.9	2.70	0.188
61.1	3.31	0.190
51.7	4.26	0.193
48.3	4.55	0.194
43.2	5.37	0.195

Table C.8 (Continued)

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-502)
38.6	3.23	0.294
44.5	3.18	0.289
50.5	2.48	0.284
50.5	2.48	0.284
60.2	2.21	0.276
59.1	2.22	0.276
66.8	1.87	0.270
66.6	1.84	0.270
74.0	1.53	0.264
74.2	1.58	0.263
82.2	1.45	0.256
82.4	1.42	0.256
90.4	1.29	0.250
90.7	1.26	0.250

Table C.9: Experimental density data for R-502/150 SUS naphthenic oil solutions

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-502)
57.5	0.876	0.000
104.0	0.849	0.000
104.3	0.849	0.000
117.8	0.841	0.000
134.1	0.832	0.000
135.8	0.831	0.000
143.9	0.826	0.000
144.4	0.826	0.000
115.0	0.843	0.000
108.7	0.846	0.000
73.2	0.866	0.000
51.7	0.878	0.000
146.1	0.856	0.087
135.6	0.865	0.087
124.9	0.873	0.088
114.2	0.881	0.089
103.6	0.888	0.090
92.7	0.897	0.091
82.7	0.904	0.092
72.4	0.912	0.093
60.7	0.920	0.094
53.9	0.926	0.094
44.1	0.932	0.096
41.8	0.933	0.096
111.3	0.911	0.180
102.3	0.918	0.181
93.7	0.925	0.182
84.7	0.933	0.184
75.8	0.939	0.186
67.1	0.946	0.188
58.8	0.954	0.190
48.8	0.961	0.193
45.2	0.964	0.194
39.7	0.968	0.195

Table C.9 (Continued)

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-502)
34.8	0.979	0.294
41.1	0.975	0.289
47.5	0.968	0.284
47.5	0.968	0.284
56.6	0.959	0.276
56.7	0.959	0.276
64.7	0.951	0.270
64.7	0.950	0.270
72.6	0.943	0.264
72.7	0.943	0.263
81.4	0.934	0.256
81.4	0.934	0.256
90.1	0.926	0.250
90.1	0.926	0.250

Table C.10: Experimental solubility (vapor pressure) data for R-502/150 SUS alkyl-benzene solutions

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-502)
43.7	0.000	0.000
44.0	0.000	0.000
44.0	0.000	0.000
70.9	0.000	0.000
72.6	0.000	0.000
98.9	0.000	0.000
99.5	0.000	0.000
81.2	0.000	0.000
81.2	0.000	0.000
117.6	0.000	0.000
117.6	0.000	0.000
135.3	0.000	0.000
135.3	0.000	0.000
148.4	0.000	0.000
148.4	0.000	0.000
148.4	0.000	0.000
151.7	1.983	0.092
137.1	1.788	0.092
137.0	1.785	0.092
136.8	1.782	0.092
122.7	1.590	0.093
122.6	1.589	0.093
109.4	1.427	0.093
109.3	1.424	0.094
95.6	1.246	0.095
82.2	1.079	0.096
68.3	0.916	0.097
56.3	0.806	0.098
49.2	0.740	0.099
47.0	0.695	0.100
140.9	3.238	0.181
141.0	3.239	0.181
127.6	2.891	0.182
127.5	2.889	0.182

Table C.10 (Continued)

Temperature (C)	Pressure (MPa)	Concentration (mass fraction R-502)
113.7	2.535	0.183
113.6	2.534	0.183
100.2	2.212	0.185
100.1	2.209	0.185
86.6	1.897	0.187
86.4	1.889	0.187
68.9	1.503	0.190
68.6	1.492	0.190
58.6	1.279	0.192
49.1	1.092	0.193
41.6	0.968	0.195
103.6	3.177	0.262
103.6	3.178	0.262
94.9	2.882	0.266
94.9	2.882	0.266
86.3	2.602	0.270
86.2	2.598	0.270
77.1	2.303	0.275
76.9	2.295	0.275
68.2	2.029	0.280
68.0	2.024	0.280
59.4	1.775	0.284
59.2	1.767	0.284
49.8	1.503	0.289
41.5	1.285	0.293
82.1	3.371	0.428
76.6	3.078	0.431
67.8	2.631	0.436
59.5	2.253	0.440
49.4	1.839	0.444
49.3	1.837	0.444
39.3	1.485	0.447

Table C.11: Experimental viscosity data for R-502/150 SUS alkylbenzene solutions

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-502)
47.0	17.21	0.000
47.2	16.68	0.000
46.6	17.26	0.000
72.5	6.91	0.000
74.0	6.56	0.000
98.9	3.52	0.000
99.5	3.46	0.000
82.1	5.21	0.000
82.1	5.22	0.000
117.6	2.39	0.000
117.6	2.40	0.000
135.3	1.79	0.000
135.3	1.78	0.000
148.4	1.46	0.000
148.4	1.47	0.000
148.4	1.46	0.000
148.3	0.96	0.092
133.8	1.18	0.092
119.9	1.46	0.093
106.8	1.82	0.094
93.6	2.27	0.095
81.4	3.03	0.096
68.9	4.09	0.097
58.1	5.49	0.098
51.8	6.84	0.099
49.7	7.25	0.100
137.9	0.83	0.181
124.8	0.99	0.182
111.2	1.22	0.183
98.0	1.50	0.185
85.4	1.89	0.187
69.3	2.64	0.190
60.3	3.52	0.192
44.8	5.51	0.195

Table C.11 (Continued)

Temperature (C)	Viscosity (cP)	Concentration (mass fraction R-502)
100.6	1.01	0.262
92.6	1.21	0.266
84.9	1.34	0.270
76.5	1.56	0.275
68.6	1.74	0.280
60.7	1.98	0.284
52.2	2.39	0.289
44.6	2.85	0.293
80.2	0.74	0.428
75.5	0.80	0.431
67.7	0.91	0.436
60.5	1.01	0.440
50.9	1.18	0.444
50.5	1.19	0.444
40.8	1.40	0.447

Table C.12: Experimental density data for R-502/150 SUS alkylbenzene solutions

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-502)
43.7	0.852	0.000
44.0	0.852	0.000
44.0	0.852	0.000
70.9	0.834	0.000
72.6	0.833	0.000
98.9	0.815	0.000
99.5	0.815	0.000
81.2	0.827	0.000
81.2	0.827	0.000
117.6	0.803	0.000
117.6	0.803	0.000
135.3	0.791	0.000
135.3	0.791	0.000
148.4	0.782	0.000
148.4	0.782	0.000
148.4	0.782	0.000
148.3	0.815	0.092
133.8	0.826	0.092
119.9	0.835	0.093
106.8	0.844	0.094
93.6	0.854	0.095
80.4	0.863	0.096
67.2	0.873	0.097
55.6	0.880	0.098
48.9	0.885	0.099
46.6	0.887	0.100
137.9	0.856	0.181
124.8	0.866	0.182
111.2	0.878	0.183
98.0	0.888	0.185
84.8	0.898	0.187
67.5	0.914	0.190
57.9	0.921	0.192
41.4	0.935	0.195

Table C.12 (Continued)

Temperature (C)	Density (g/mL)	Concentration (mass fraction R-502)
100.6	0.887	0.262
92.5	0.896	0.266
84.2	0.905	0.270
75.3	0.914	0.275
66.8	0.922	0.280
58.4	0.931	0.284
49.3	0.939	0.289
41.2	0.948	0.293
30.3	0.951	0.428
75.1	0.957	0.431
66.6	0.967	0.436
58.5	0.975	0.440
48.8	0.986	0.444
48.8	0.986	0.444
39.1	0.999	0.447